



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



11X0009020110809

BUTLER

NEW MIAMI WTP

SARLE, EDWARD

2011/08/09



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 9, 2011

Mr. Howard Beare
New Miami WTP
268 Whitaker Avenue
New Miami, Ohio 45011

Re: Butler County, New Miami WTP, NPDES Permit Violations

Dear Mr. Beare:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of September 2010 through June 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0096695; OEPA Permit # 11X00090*DD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations for September 2010 through June 2011					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
January 2011	pH	Daily	S.U.	9.0	13

Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle
Division of Surface Water
Permit Section