

Sewage



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 9, 2009

Mr. Jerome Conley, Mayor
City of Oxford
101 East High Street
Oxford, Ohio 45056-1887

Re: Butler County, City of Oxford WWTP, NPDES Permit Violations

Dear Mr. Conley:

We have received your Monthly Operating Reports covering the month of November 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0026930; OEPA Permit # 1PD00007*LD). The specific instance of noncompliance was as follows:

Effluent Limit Violations						
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value	
November 2008	TSS	Weekly	mg/l	45	74	

Please be advised that failure to comply with the effluent limitations of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285 - 6096.

Sincerely,

~~Ned Sarle~~
Division of Surface Water
Permit Section

cc: Jeff Ratliff, City of Oxford

