



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 19, 2007

Ms. Susan Vance, Director
Butler County Environmental Services Department
130 High Street, 6th Floor
Hamilton, Ohio 45011

Re: Butler County, Queen Acres WWTP, Self-Monitoring Report Notice of Violation- July 2007 through September 2007

Dear Ms. Vance:

We have reviewed your Monthly Operating Reports (MORs) covering the months of July through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0024261; OEPA Permit # 1PG00043*ED). The specific instances of noncompliance and deficiencies was/were as follows:

Effluent Limit Violations					
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value
July 2007	001	Dissolved Oxygen	1D Conc	7.0	6.8
August 2007	001	Dissolved Oxygen	1D Conc	7.0	6.9
August 2007	001	Dissolved Oxygen	1D Conc	7.0	6.9
August 2007	001	Dissolved Oxygen	1D Conc	7.0	6.8
August 2007	001	Dissolved Oxygen	1D Conc	7.0	6.5

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."



Ms. Susan Vance
November 19, 2007
Page 2

If you have any questions regarding the above, please contact me at (937) 285-9749.

Sincerely,

A handwritten signature in cursive script that reads "Laura Pohlman". The signature is written in black ink and is positioned above the printed name.

Laura Pohlman:
Division of Surface Water
Permit Section

cc: Brian Custer, Butler County Environmental Services Department