



State of Ohio Environmental Protection Agency

sewage

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 2, 2009

Ms. Mary Gerbus
The Pines Park, Inc.
11779 Stone Mill Road
Cincinnati, Ohio 45251

Re: Butler County, ~~The Pines MHP~~, NPDES Permit Violations

Dear Ms. Gerbus:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of December 2008 through October 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0127329; OEPA Permit # 1PV00107*BD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
October 2009	Ammonia	Monthly	mg/l	1.0	3.8
October 2009	Ammonia	Weekly	mg/l	1.5	3.8
October 2009	Ammonia	Monthly	kg/day	0.089	0.27
October 2009	Ammonia	Weekly	kg/day	0.13	0.27

Please be advised that failure to comply with the effluent limitations or to satisfy the reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

NPDES Permit violations may also be reported in accordance to the new Ohio EPA reporting requirements. These reporting requirements are addressed at the following Ohio EPA website: http://www.epa.state.oh.us/dsw/permits/24-hour_Report_FactSheet.pdf.

Ms. Mary Gerbus
December 2, 2009
Page 2

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle
Division of Surface Water
Permit Section

cc: Andy Griner, Winelco, Inc.