



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PX0004720080117

CHAMPAIGN SPRING MEADOWS CARE CENTER

MILLER, JOSEPH

2008/01/17



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 17, 2008

Spring Meadows Care Center
Jim Griffiths, Administrator
1649 Park Road
Woodstock, OH 43084

RE: **NOTICE OF VIOLATION**
Spring Meadows Care Center Wastewater Treatment Plant
NPDES Permit #1PX00047*AD/OH0134180
Champaign County

Dear Mr. Griffiths,

Ohio EPA has reviewed your monthly operating reports for the period of January 2006 to November 2007 for the above referenced facility. Our review indicates violations of your NPDES permit (1PX00047*AD/OH0134180). The specific instances of noncompliance are as follows:

Effluent Limitation Violations

Permit No.	Reporting Period	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
1PX00047*AD	January 2006	00530	Total Suspended Solids	30D Conc	12	14.	1/1/2006
1PX00047*AD	June 2006	00400	pH	1D Conc	9.0	9.1	6/19/2006
1PX00047*AD	June 2007	00400	pH	1D Conc	9.0	9.4	6/1/2007
1PX00047*AD	June 2007	00400	pH	1D Conc	9.0	9.4	6/25/2007
1PX00047*AD	July 2007	00400	pH	1D Conc	9.0	9.2	7/5/2007
1PX00047*AD	July 2007	00400	pH	1D Conc	9.0	9.1	7/25/2007
1PX00047*AD	August 2007	00400	pH	1D Conc	9.0	9.1	8/1/2007
1PX00047*AD	August 2007	00400	pH	1D Conc	9.0	9.1	8/23/2007
1PX00047*AD	September 2007	00400	pH	1D Conc	9.0	9.3	9/4/2007
1PX00047*AD	September 2007	00400	pH	1D Conc	9.0	9.2	9/26/2007
1PX00047*AD	October 2007	00400	pH	1D Conc	9.0	9.3	10/1/2007
1PX00047*AD	October 2007	00400	pH	1D Conc	9.0	9.7	10/19/2007
1PX00047*AD	November 2007	00400	pH	1D Conc	9.0	9.5	11/1/2007
1PX00047*AD	November 2007	00400	pH	1D Conc	9.0	9.2	11/21/2007

Also, improper flow values were reported in August 2007. Flow was reported in million gallons per day (MGD), rather than gallons per day (GPD) as required by your NPDES permit.




Effluent Frequency Violations

Reporting Period	Reporting Code	Parameter	Sample Frequency	Expected	Reported	Violation Date
January 2006	80082	CBOD 5 day	1/Month	1	0	01/01/2006
February 2006	80082	CBOD 5 day	1/Month	1	0	02/01/2006
February 2006	00010	Water Temperature	1/Week	1	0	02/15/2006
March 2006	80082	CBOD 5 day	1/Month	1	0	03/01/2006
April 2006	80082	CBOD 5 day	1/Month	1	0	04/01/2006
May 2006	80082	CBOD 5 day	1/Month	1	0	05/01/2006
June 2006	80082	CBOD 5 day	1/Month	1	0	06/01/2006
July 2006	80082	CBOD 5 day	1/Month	1	0	07/01/2006
August 2006	80082	CBOD 5 day	1/Month	1	0	08/01/2006
September 2006	80082	CBOD 5 day	1/Month	1	0	09/01/2006
October 2006	80082	CBOD 5 day	1/Month	1	0	10/01/2006
November 2006	80082	CBOD 5 day	1/Month	1	0	11/01/2006
December 2006	80082	CBOD 5 day	1/Month	1	0	12/01/2006
January 2007	80082	CBOD 5 day	1/Month	1	0	01/01/2007
February 2007	80082	CBOD 5 day	1/Month	1	0	02/01/2007
March 2007	80082	CBOD 5 day	1/Month	1	0	03/01/2007
April 2007	80082	CBOD 5 day	1/Month	1	0	04/01/2007
May 2007	80082	CBOD 5 day	1/Month	1	0	05/01/2007
June 2007	80082	CBOD 5 day	1/Month	1	0	06/01/2007
July 2007	80082	CBOD 5 day	1/Month	1	0	07/01/2007
August 2007	80082	CBOD 5 day	1/Month	1	0	08/01/2007
September 2007	80082	CBOD 5 day	1/Month	1	0	09/01/2007
October 2007	80082	CBOD 5 day	1/Month	1	0	10/01/2007
November 2007	80082	CBOD 5 day	1/Month	1	0	11/01/2007

Please inform this office, in writing, as to the reasons for the aforementioned violations, as well as a description of the action taken or proposed to prevent further violations. Your response should include the dates, either actual or proposed, for completion of actions. Your response should be provided by **February 15, 2007**. Future violations need to be reported as per your NPDES Permit. See Part III, Item 12 of your NPDES Permit, entitled "Non-Compliance Notification".

Should you have any questions, I can be reached at (937) 285-6109.

Sincerely,



Joe Miller
Division of Surface Water

CC: Chris Woodell, Wastewater Operator
Champaign County Health Department

