



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korteski, Director



\*1PT0006620080102\*

CHAMPAIGN WEST LIBERTY SALEM SCHOOL

MILLER, JOSEPH

2008/01/02



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 2, 2008

West Liberty Salem School  
7208 State Route 68  
West Liberty, OH 43357

RE: **NOTICE OF VIOLATION**  
**West Liberty Salem School Wastewater Treatment Plant**  
**NPDES Permit #1PT00066\*BD/OH0096601, Champaign County**

Ladies and Gentlemen,

Ohio EPA has reviewed your monthly operating reports for the period of January 2007 to November 2007 for the above referenced facility. Our review indicates violations of your NPDES permit (1PT00066\*BD/OH0096601). The specific instances of noncompliance are as follows:

Permit No	Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
1PT00066*BD	May 2007	Chlorine, Total Residual	1D Conc	0.019	0.07	5/9/2007
1PT00066*BD	May 2007	Chlorine, Total Residual	1D Conc	0.019	0.06	5/18/2007
1PT00066*BD	June 2007	Dissolved Oxygen	1D Conc	7.0	6.6	6/1/2007
1PT00066*BD	November 2007	CBOD 5 day	30D Conc	5.0	7.66667	11/1/2007
1PT00066*BD	November 2007	CBOD 5 day	7D Conc	8.0	13.0	11/1/2007

Mr. Robert Harrison, your certified wastewater operator, has provided self-notification of these effluent violations as required by your permit. In addition, Mr. Harrison has detailed the plans for addressing these violations. No further information is required at this time. Should you have any questions, I can be reached at (937) 285-6109.

Sincerely,

Joe Miller  
Division of Surface Water

CC: Robert Harrison, Wastewater Operator  
Champaign County Health Department

