



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PV0009820070705

CLARK

CLEARVIEW MHP

LEIBFRITZ, SANDRA 2007/07/05



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

July 5, 2007

Jeff Ulery, Owner
3090 East Possum Road
Springfield, OH 45502

CERTIFIED LETTER

**Re: Self-Monitoring Report NOV - April 2007 through May 2007 - Clark County
Clearview MHP - NPDES No. 1PV00098*BD/OH0122939**

Dear Mr. Ulery:

We have received your self-monitoring reports covering the months of April 2007 through May 2007 for the above-referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and deficiencies were as follows:

EFFLUENT LIMIT VIOLATIONS FOR OUTFALL 001


Reporting Period	Parameter	Limit Type	Limit	Reported Value
May 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	6.8
May 2007	Nitrogen, Ammonia (NH3)	30D Qty	0.06	.36033
May 2007	Fecal Coliform	30D Conc	1000	4300.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions regarding the above, please contact me at (937) 285-6104.

Respectfully,


Sandra D. Leibfritz
Division of Surface Water

cc: Clark County Health Department
Kevin Miller, Operator

