



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PX0005420101207

CLINTON

BUDGET INN

WARE, RONALD

2010/12/07

**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

December 7, 2010

Budget Inn
Attn: Sunny Patel, owner
264 West Curry Road
Wilmington, Ohio 45177

**Re: Budget Inn, 264 West Curry Road, Clinton Co.
Reconnaissance Inspection**

Dear Mr. Patel:

On Tuesday, November 30, 2010, I conducted a Reconnaissance Inspection of the wastewater treatment plant that serves the above referenced facility in Liberty Township, Clinton County (NPDES Permit No. 1PX00054, OH0137421). Harry McVey, the contract operator for this facility, was present during the inspection. The purpose of this inspection was to evaluate plant operation and performance. A copy of the inspection report is enclosed.

All components of the treatment plant were operational, and the effluent appeared to be clear and free of solids. No response or corrective action is required at this time.

A draft renewal of the NPDES permit for this facility (1PX00054*BD) was sent to public notice on November 18, 2010. This renewal permit has the following changes:

Effluent Disinfection Standard

Due to recent changes in the State of Ohio's Water Quality Standards, the disinfection standard in NPDES permits has been changed from fecal coliform to *E. coli*. For your treatment plant, the applicable *E. coli* standards will be 161 counts/100 ml (monthly geometric mean) and 362 counts/100/ ml (weekly geometric mean). If you are unsure of your treatment plant's ability to meet these new disinfection standards, please inform this office during the 30 day public notice period for this renewal permit (which will end on Thursday, December 23, 2010).

Mr. Patel

December 7, 2010

Page 2

Operator of Record Requirements


The renewal NPDES permit for this wastewater treatment plant will require that a Class A certified wastewater operator to be the "Operator of Record" for this treatment plant. This new NPDES permit will also require that the operator of record be physically present at the treatment works in accordance with the minimum staffing requirements included in paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code. For Class A facilities, the minimum staffing requirements are 2 days a week for a minimum of 1 hour.

In addition, Ohio Administrative Code 3745-7-09 requires that the owner and the operator of record of a wastewater treatment works maintain operation and maintenance records for the treatment works within the treatment works site. These records are to be housed and maintained in such a manner as to be protected from weather damage and to guarantee the authenticity and accuracy of the records (as required by Ohio Administrative Code 3745-7-09).

Arrangements need to be made to ensure that these minimum staffing requirements are being met for this treatment plant. A record keeping logbook that meets the authenticity criteria referenced in Ohio Administrative Code 3745-7-09 also needs to be provided for this treatment plant. Please notify the Ohio EPA Southwest District Office no later than January 14, 2011 as to how and when these requirements will be met.

If you have any questions regarding this report, please contact me at (937) 285-6098.

Sincerely,



Ron Ware
Ohio EPA - Division of Surface Water
Southwest District Office

RW/ka

cc: Stan Bolka and Harry McVey, City of Wlilmington
Clinton County Health District



State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report
Semi-Public Sewage Disposal Inspection Form

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PX00054*AD	OH0137421	11/30/2010	R	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Budget Inn 264 West Curry Road Clinton County, Liberty Township	10:15 AM	12/1/2005
	Exit Time	Permit Expiration Date
	10:30 AM	11/30/2010
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Harry McVey, plant operator	(937) 302 - 0742	
Name(s), Address and Title(s) of Operator of Record	Phone Number(s)	
Stanley Bolka, Operator of Record	(937) 382 - 2413	
Name, Address and Title of Responsible Official	Phone Number	
Budget Inn Attn: Sunny Patel, owner 264 West Curry Road Wilmington, Ohio 45177	((937) 382 - 3783	

Ohio EPA Inspector	
<i>Ron Ware</i> <i>12/7/10</i>	
Ron Ware Date Division of Surface Water Southwest District Office	

Permit # 1PX00054*AD
 NPDES# OH0137421

Average Daily Design Flow:	24,800 Gallons/Day
Plant Serves:	Motel
Average Daily Flow: (Period of Review):	2,162 Gallons/Day (July 2009 thru October 2010)
Method of flow monitoring:	None
Type of alarms for plant:	None

Pretreatment

Type of Pretreatment: **Trash Trap**
 Does the Trash Trap need pumped: **Unknown**
 Maintenance of pretreatment components appears to be: **Good**

Comments/Status:

**Secondary Treatment
(Aeration)**

Color of sludge: **Other**
 Quality of Sludge: **Thin**
 Foam: **None present**
 Odor: **No objectionable odor present**

	Yes	No		Yes	No
Aeration is taking place	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Plant is septic	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Blowers are operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Blowers are on a timer	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Skimmers are operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Plant is flooded	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Diffusers are operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Grating is present	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Sludge return is operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>			

Maintenance of aerating equipment appears to be: **Good**

Comments/Status:

**Secondary Treatment
 (Settling)**

Clarity: **Clear**
 Condition of Weir: **Clean**
 Weir is level: **Yes**
 Effluent in weir: **Clear**
 Clarifier walls need to be scraped: **Unknown**

Overall maintenance of settling components appears to be: **Good**

Comments/Status:

Tertiary Treatment

	Yes	No		Yes	No
Surface sand Filters: Slow	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Subsurface	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	<input type="checkbox"/>	<input type="checkbox"/>	Beds alternated	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Are filters ponding/flooding	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Beds raked	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Sand filters overgrown	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Chlorination present	<input type="checkbox"/>	<input checked="" type="checkbox"/>
UV present	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Dechlorination present	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Overall maintenance of components appears to be: **Fair**

Comments/Status:

Sludge Handling/Storage Disposal

Hauler name: **Unknown**
 Sludge wasted from: **Sludge return line**
 Sludge drying beds: **Yes** Sludge holding tank: **Yes**

Overall maintenance of components appears to be: **Good**

Comments/Status:

Little to no waste sludge to manage.

