



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PE0000820090219

CLERMONT MOSCOW VILLAGE

WALLER, MICHELLE 2009/02/19



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

February 17, 2009

Mayor and Council
Village of Moscow
P.O. Box 93
Moscow, Ohio 45153

Re: Village of Moscow, NPDES Permit Violations

Dear Sirs:

We have reviewed your Monthly Operating Reports (MORs) covering the months of January 2007 through January 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0096571; OEPA Permit # 1PE00008*CD). The specific instances of noncompliance and deficiencies were as follows:

Effluent Limit Violations

Reporting Period	Parameter	Limit Type	Unit	Limit	Reported Value
March 2007	Total Suspended Solids	7D Conc	mg/l	65	92.
September 2007	pH	1D Conc	S.U.	9.0	9.1
September 2007	pH	1D Conc	S.U.	9.0	9.4
May 2007	Total Suspended Solids	7D Conc	mg/l	65	79.5
May 2007	pH	1D Conc	S.U.	9.0	9.1
August 2007	Fecal Coliform	30D Conc	#/100 ml	200	233.3
May 2008	pH	1D Conc	S.U.	9.0	9.3
May 2008	pH	1D Conc	S.U.	9.0	9.4
May 2008	pH	1D Conc	S.U.	9.0	9.2
May 2008	pH	1D Conc	S.U.	9.0	9.5
July 2008	Total Suspended Solids	7D Conc	mg/l	65	77.2
February 2008	Total Suspended Solids	7D Qty	mg/l	5.9	6.12659
February 2008	Total Suspended Solids	7D Qty	mg/l	5.9	5.98446
March 2008	Total Suspended Solids	7D Qty	mg/l	5.9	6.16879
September 2008	pH	1D Conc	S.U.	9.0	9.2
October 2007	Total Suspended Solids	7D Qty	mg/l	5.9	8.91844
October 2007	pH	1D Conc	S.U.	9.0	9.2

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement



action pursuant to the Ohio Revised Code Chapter 6111.

Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6028.

Sincerely,

A handwritten signature in cursive script that reads "Michelle Waller".

Michelle Waller
Division of Surface Water
Permit Section