



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PB0002220090420

CLERMONT NEW RICHMOND STP

JACKSON, JOSHUA 2009/04/20



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

April 20, 2009

Mayor & Council
Village of New Richmond
102 Willow Street
New Richmond, OH 45157 *C. Korfeski*

Re: **New Richmond wastewater treatment works, Self-monitoring Report Violations
NPDES Permit # OH0021156; OEPA Permit # 1PB00022*GD**

Ladies & Gentlemen:

We have reviewed your self-monitoring reports covering the months of December 2008 through February 2009 for the referenced facility. Our review indicates a violation of the conditions of your NPDES Permit. The specific instance of noncompliance was as follows:

**EFFLUENT LIMIT VIOLATIONS
(Period of Review: December 2008 – February 2009)**

7D = Weekly 30D = Monthly 1D = Daily Conc. = Concentration (mg/l) Qty. = Quantity (Kg/Day)

Reporting Period	Parameter	Limit Type	Limit	Reported Value
February 2009	pH	1D Conc	9.0	9.6


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

Mayor & Council
Page 2

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,

A handwritten signature in black ink, appearing to read 'Joshua Jackson', written in a cursive style.

Joshua Jackson
Environmental Specialist II
Division of Surface Water

cc: Ken Sherwood, Village of New Richmond