



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PX0001020090714

CLINTON

THOUSAND TRAILS INC WILMINGTON
PRESERVE WWTP

WARE, RONALD

2009/07/14



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6248
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

July 14, 2009

Ms. Amy Bass
Thousand Trails, LP
1786 State Route 380
Wilmington, Ohio 45177

**Re: Thousand Trails WWTP, 295 Todd Fork Road, Adams Twp., Clinton Co.
Reconnaissance Inspection**

Dear Ms. Bass:

On Friday, July 10, 2009, I conducted a Reconnaissance Inspection of the wastewater treatment plant that serves the above referenced facility in Adams Township, Clinton County (NPDES Permit No. 1PX00010, OH0085863). Harry McVey, the contract operator for this facility, was present during the inspection. The purpose of this inspection was to evaluate plant operation and performance. A copy of the inspection report is enclosed. As indicated in the attached report, two areas evaluated during the inspection were rated "unsatisfactory."

"Effluent/Receiving Waters" received an "unsatisfactory" rating due to violations of the final effluent limitations for ammonia nitrogen in this facility's current NPDES permit (1PX00010*DD) that have occurred over the past year. "Records/Reports" received an "unsatisfactory" rating due to the non-reporting of these final effluent violations.

Please provide this office with a written description of any actions, either taken or proposed, to prevent any further final effluent violations. This written description should include the dates, either actual or proposed, for completion of these actions. Please provide this written description within thirty days of the receipt of this letter.

If you have any questions regarding this report, please contact me at (937) 285-6098.

Sincerely,

Ron Ware
Division of Surface Water

cc: Stan Bolka and Harry McVey, City of Wilmington
Clinton County Health District

RW/rif



Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
1PX00010*DD	May 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	0.5	5.32	5/1/2008
1PX00010*DD	May 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.02	.23046	5/1/2008
1PX00010*DD	May 2008	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.0	5.32	5/22/2008
1PX00010*DD	May 2008	001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.05	.23046	5/22/2008
1PX00010*DD	July 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	0.5	1.87	7/1/2008
1PX00010*DD	July 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.02	.04696	7/1/2008
1PX00010*DD	July 2008	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.0	1.87	7/15/2008
1PX00010*DD	August 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	0.5	1.28	8/1/2008
1PX00010*DD	August 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.02	.03332	8/1/2008
1PX00010*DD	August 2008	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.0	1.28	8/1/2008
1PX00010*DD	September 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	0.5	1.28	9/1/2008
1PX00010*DD	September 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.02	.02427	9/1/2008
1PX00010*DD	September 2008	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.0	1.28	9/22/2008
1PX00010*DD	September 2008	001	50060	Chlorine, Total Residu	1D Conc	0.019	.08	9/24/2008
1PX00010*DD	October 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	0.5	1.69	10/1/2008
1PX00010*DD	October 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.02	.03648	10/1/2008
1PX00010*DD	October 2008	001	00610	Nitrogen, Ammonia (NH3	7D Conc	1.0	1.69	10/22/2008