



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

February 2, 2012

RE: MEDINA COUNTY  
OUR SAVIOR LUTHERAN CHURCH  
NTNC WATER SYSTEM  
PWS ID # OH5242212  
LEAD AND COPPER

**VIOLATION NOTIFICATION**

Pastor Scott Silcox  
Our Savior Lutheran Church  
1605 Center Rd.  
P.O. Box 278  
Hinckley, OH 44233

**Subject: Failure to Perform and Submit Water Quality Parameters/Corrosion Control Recommendation/Source Water Treatment Recommendation/Detail Plans for Corrosion Control Equipment**

Dear Pastor Silcox:

This letter is notification that the Our Savior Lutheran Church water system is in violation of the Ohio Administrative Code (OAC) for failure to perform lead and copper Water Quality Parameter and Entry Point Monitoring, and for failure to submit a Corrosion Control/Source Water Treatment Recommendation and Detail Plans as specified in OAC rules 3745-81-80 through 3745-81-89.

In order to avoid any further violations, you must complete the following:

1. Within 30 days, monitor with a minimum of two samples for each applicable water quality parameter from:
  - a. Each entry point to the distribution system; and
  - b. One site(s) in the distribution system.

The parameters to measure are pH, water temperature, alkalinity, calcium, conductivity, orthophosphate (when a phosphate inhibitor is used), and silica (when a silicate-containing inhibitor is used).

In addition, monitor with a minimum of one sample for lead and copper at each entry point to the distribution system. Report the results to Ohio EPA, Northeast District Office on form 5108 within 30 days.

Issue the enclosed public notice and return a copy of the public notice distributed and the verification form to this office within 30 days.

OUR SAVIOR LUTHERAN CHURCH  
FEBRUARY 2, 2012  
PAGE 2

2. Submit the required Corrosion Control Recommendation and Detail Plans for optimal corrosion control treatment and equipment no later than March 31, 2012.
3. Submit a Source Water Treatment Recommendation no later than March 31, 2012.

If you have any questions regarding this letter, please contact me at (330) 963-1202.

Sincerely,



Anne Karney  
Environmental Specialist  
Division of Drinking and Ground Waters

AK/ams

Enclosure: Form 5108, PN and Verification Form

cc: Kim Etters, Ohio EPA, NEDO, DDAGW  
Dan Underwood, Ohio EPA, NEDO, DDAGW