



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 4, 2008

Mayor and Council  
Village of Rushsylvania  
P.O. Box 204  
Rushsylvania, OH 43347

RE: **NOTICE OF VIOLATION**  
**Village of Rushsylvania Wastewater Treatment Plant**  
**NPDES Permit #1PB00025\*ED/OH0020575, Logan County**

Ladies and Gentlemen,

Ohio EPA has reviewed your monthly operating reports for the period of February 2007 to November 2007 for the above referenced facility. Our review indicates violations of your NPDES permit (1PB00025\*ED/OH0020575). The specific instances of noncompliance are as follows:

Permit No.	Reporting Period	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
1PB00025*ED	August 2007	31616	Fecal Coliform	30D Conc	1000	10000.	8/1/2007
1PB00025*ED	August 2007	31616	Fecal Coliform	7D Conc	2000	10000.	8/1/2007
1PB00025*ED	August 2007	50060	Chlorine, Total Residual	1D Conc	0.021	0.06	8/28/2007
1PB00025*ED	August 2007	50060	Chlorine, Total Residual	1D Conc	0.021	0.05	8/29/2007
1PB00025*ED	August 2007	50060	Chlorine, Total Residual	1D Conc	0.021	0.05	8/30/2007
1PB00025*ED	September 2007	50060	Chlorine, Total Residual	1D Conc	0.021	0.05	9/26/2007

Provide an update on wastewater improvements to avoid future violations. Your response should be provided by **January 25, 2008**. Future violations need to be reported as per your NPDES Permit. See Part III, Item 12 of your NPDES Permit, entitled "Non-Compliance Notification". Should you have any questions, I can be reached at (937) 285-6109.

Sincerely,

Joe Miller  
Division of Surface Water

CC: Bill Boyle, GGJ Consulting Engineers

