



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 2, 2009

Mayor and Council
Village of Rushsylvania
P.O. Box 204
Rushsylvania, Ohio 43347

RE: Rushsylvania Waste Water Treatment Plant Notice of Violation.

Dear Mayor and Council,

Ohio EPA has reviewed your Electronic Discharge Monitoring Reports (EDMR's) for the period of January 1, 2008 through December 31, 2008. Our review indicates violations of your National Pollutant Discharge Elimination System (NPDES) permit (1PB00025 / OH0020575). The specific instances of non-compliance are as follows:

Date	Station	Parameter	Permit Limit	Reported	Freq.
5/1/2008	001	Ammonia	1.4 mg/l	2.0 mg/l	Mo.
5/1/2008	001	Ammonia	0.53 kg/day	0.58 kg/day	Mo.
5/8/2008	001	CBOD5	15 mg/l	17 mg/l	Wk.
5/8/2008	001	CBOD5	5.7 kg/day	8.4 kg/day	Wk.
5/15/2008	001	Ammonia	2.1 mg/l	3.7 mg/l	Wk.
5/15/2008	001	Ammonia	0.8 kg/day	1.1 kg/day	Wk.
6/1/2008	001	Fecal Col.	1000 #/100 ml	5400 #/100	Mo.
6/8/2008	001	Fecal Col.	2000 #/100 ml	5400 #/100	Mo.
10/11/2008	001	Chlor. Res.	0.021 mg/l	0.12 mg/l	Daily
10/12/2008	001	Chlor. Res.	0.021 mg/l	0.34 mg/l	Daily
10/13/2008	001	Chlor. Res.	0.021 mg/l	0.15 mg/l	Daily
10/14/2008	001	Chlor. Res.	0.021 mg/l	0.14 mg/l	Daily
10/15/2008	001	Chlor. Res.	0.021 mg/l	0.07 mg/l	Daily

Mayor and Council
Village of Rushsylvania
March 2, 2008
Page 2

A written response detailing the actions taken or proposed to prevent further violations must be submitted to this office by no later than March 30, 2009. If you have any questions, please call me at (937) 285 – 6097.

Sincerely,

A handwritten signature in black ink, appearing to read "Joseph Reynolds". The signature is fluid and cursive, with a long horizontal stroke at the end.

Joseph Reynolds
Division of Surface Water

cc: Dave Wilson, Plant Operator
William Boyle, GGJ Inc.