



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



11J0004820080118

MIAMI

BARRETT PAVING MATERIALS INC *

REYNOLDS, JOSEP 2008/01/18

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

January 18, 2008

Mr. Jim Mecstroth
Barrett Paving, Ludlow Falls Quarry
P.O. Box 13671
2589 Needmore Road
Dayton, Ohio 45365

Dear Mr. Mecstroth:

I am writing to correct an error in the OEPA inspection letter dated January 16, 2008. This letter was in reference to the inspection conducted at the Barrett Paving, Ludlow Falls quarry located at 3244 Davis Road, Miami County.

The facility Storm Water Pollution Prevention Plan was available at the time of the inspection and was reviewed by the inspector. The plan was acceptable. You do not need to submit a copy of it to this office. Please disregard this request. Finally a copy of the daily inspection logs for April, 2007 should still be provided.

If you have any questions, please call me at (937) 285 - 6097.

Sincerely,

Joseph Reynolds
Division of Surface Water, SWDO

cc: Jeff Kessler, Plant Superintendent





State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

January 16, 2008

Mr. Jim Mecstroth
Barrett Paving, Ludlow Falls Quarry
P.O. Box 13671
2589 Needmore Road
Dayton, Ohio 45365

Dear Mr. Mecstroth:

On January 8, 2008 Mr. Joseph Reynolds of this office inspected the Barrett Paving, Ludlow Falls quarry located at 3244 Davis Road, Miami County. The inspection was performed as part of the National Pollutant Discharge Elimination System (NPDES) permit renewal process. The inspection report is attached.

The facility Storm Water Pollution Prevention Plan was not readily available at the time of the inspection. A copy of the plan needs to be submitted to this office by no later than January 28, 2008. In addition to the plan a copy of the daily inspection logs for April, 2007 should be provided.

A copy of the draft renewal NPDES permit will be sent to Barrett Paving for review and comment. All comments concerning the draft must be received by no later than 30 days from the public notice date. If you have any questions, please feel free to contact Mr. Reynolds at (937) 285 - 6097.

Sincerely,

Martyn Burt, Environmental Supervisor
Division of Surface Water, SWDO

cc: Jeff Kessler, Plant Superintendent





State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
11J00048*CD	OH0115479	1/8/2008	R	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Barrett Paving, Ludlow Falls Quarry 3244 Davis Road Ludlow Falls, Ohio 45339	8:45 AM	2/1/2003
	Exit Time	Permit Expiration Date
	9:40 AM	1/31/2008
Name(s) and Title(s) of On-Site Representatives		Phone Number(s)
Jeff Kessler, Superintendent		(937) 606 - 0358
Name, Address and Title of Responsible Official		Phone Number
Jim Mecstroth, Regional Manager P.O. Box 13671 2589 Needmore Road Dayton, Ohio 45365		(937) 424 - 9100

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measurement	N	Pretreatment
S	Records/Reports	N	Laboratory	N	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	N	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)

- Barrett Paving collects storm water from two quarries located on both sides of Davis road in a large settling pond . A 40 horse power pump on pontoon is used to pump water through a 6 inch line to the settling pond. A second 40 horse power pump is used to pump effluent from the quarry to Ludlow Creek.
- Flows are estimated based upon pumping capacity, 1400 gpm.
- The final effluent is monitored at the discharge pipe outlet prior to Ludlow Creek.
- A Storm Water Pollution Prevention Plan (SWPPP) has been developed for the site.
- The final effluent was clear. There were no residual solids noted down stream of the outfall.
- Between January, 2006 and November, 2007 Barrett Paving reported 3 final effluent pH violations.

Inspector	Reviewer
 Joe Reynolds Division of Surface Water Southwest District Office Date: 1/16/08	 Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office Date: 1/16/08

