



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1IZ0001020100921

MIAMI

BRADFORD WTP

MILLER, JOSEPH

2010/09/21

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer

**Environment
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director
September 21, 2010

Mayor and Council
Village of Bradford
115 North Miami Avenue
Bradford, OH 45308

**RE: Reconnaissance Inspection (RI)/ Notice of Violation
Village of Bradford Water Treatment Plant
NPDES Permit 11Z00010*FD/OH0030465
Village of Bradford, Miami County**

Ladies and Gentlemen,


On September 15, 2010, I conducted a Reconnaissance Inspection at the Bradford Water Treatment Plant for the discharge resulting from the processing of public drinking water. This inspection was conducted to determine compliance with the NPDES discharge permit.

I have reviewed the discharge monitoring reports for the period of June 2006 to August 2010 for this facility. This review revealed violations of the effluent limitations in your NPDES permit. Non-compliance notification was provided for all incidences of non-compliance as required by the NPDES permit. The non-compliance notification included measures taken for correction of the circumstances that caused the violations.

The discharge from the water treatment facility is to the road ditch along the north side of Klinger Road. This location is poorly suited for the discharge of approximately 12,500 gallons per day of wastewater. Permit to Install #715239 for the Village of Bradford wastewater treatment plant improvements included the connection of the water treatment plant to the sanitary sewer. This connection will eliminate the need for an NPDES permit and continued monitoring of the water treatment plant discharge. When this portion of the project has been completed, contact me so I can verify the connection and revoke the NPDES permit.

At this time, a response to this inspection is not necessary. If you have any questions, I can be reached at (937) 285-6109.

Sincerely,



Joe Miller
Division of Surface Water

CC: Miami County Health Department

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov


State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
11Z00010*FD	OH0030465	8/15/2010	R	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Bradford Water Treatment Plant 11755 Klinger Road Bradford, OH 45308	1:45 PM	3/1/2007
	Exit Time	Permit Expiration Date
	1:55 PM	2/29/2012
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
N/A		
Name, Address and Title of Responsible Official	Phone Number	
Mayor and Council Village of Bradford 115 North Miami Avenue Bradford, OH 45308	937-448-2718	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	N	Flow Measurement	N	Pretreatment
S	Records/Reports	N	Laboratory	N	Compliance Schedule
N	Operations & Maintenance	M	Effluent/Receiving Waters	S	Self-Monitoring Program
N	Facility Site Review	N	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
Discharge to be eliminated	
Inspector	Reviewer
 Joe Miller Division of Surface Water Southwest District Office	 Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office
9/21/10 Date	9/23/10 Date

Bradford WTP Effluent Limitation Violations June 2006 to August 2010

Reporting Period	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
December 2008	01044	Iron, Suspended (Fe)	30D Conc	1000	4320.	12/1/2008
December 2008	01044	Iron, Suspended (Fe)	7D Conc	2000	8540.	12/1/2008



Figure 1, Location of Bradford WTP discharge, ditch on Klinger Road, JGM 9/15/10

