



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PV0001920100317

MIAMI

JGR PROPERTIES INC SUNSHINE MHP

REYNOLDS, JOSEP 2010/03/17

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korteski, Director

March 17, 2010

Mr. Pete Stojich
6104 Whiting Drive
McHenry, Illinois 60050

**RE: Sunshine MHP Notice of Violation, Permit No. 1PV00019*CD/OH0049832
Miami County**

Dear Mr. Stojich:

On March 16, 2010 the Ohio EPA was advised of a failure of the sand filters wall at Sunshine Mobile Home Park. This failure has allowed partially treated sewage to bypass from the parks waste water treatment system.

The sand filter walls reportedly collapsed sometime over the weekend (March 13 to 14). The failure was discovered on Monday morning. Upon discover a bypass of the filters was set up. A worst case over flow volume would be 100,000 gallons (2.5 days x 40,000 gpd). Failure to correct issues associated with the sand in the filters (the filters did not drain properly) are believed to be a contributing factor in the failure. I understand repairs have begun, with an anticipated completion date some time the end of this week.

The discharge of partially treated waste water is in violation of Ohio Revised Code Chapter 6111.04, "Acts of Pollution Prohibited", and the March 5, 2007 consent agreement.

A written response detailing the cause and corrective actions taken to eliminate the filter bypass must be submitted to this office by no later than April 12, 2010.

If you have any questions, please call me at (937) 285 – 6097.

Sincerely,

Joseph Reynolds
Division of Surface Water

cc: Bridget Coontz, Attorney General's Office

