



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PV0012320100115

MIAMI

LE-O-NA FALLS MHP

MILLER, JOSEPH

2010/01/15

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:



GARRY MYERS
LEONA FALLS MOBILE HOME PARK
8112 STATE ROUTE 55
LUDLOW FALLS OH 45339

2. Article Number

(Transfer from service label)

COMPLETE THIS SECTION ON DELIVERY

Signature

 Garry Myers
 Agent Addressee

B. Received by (Printed Name)

GARRY MYERS

C. Date of Delivery

1-19-2010

D. Is delivery address different from item 1? YesIf YES, enter delivery address below: No

3. Service Type

 Certified Mail Express Mail Registered Return Receipt for Merchandise Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

 Yes

UNITED STATES POSTAL SERVICE



First-Class Mail
Postage & Fees Paid
USPS
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •



JOE MILLER
OHIO EPA
401 E FIFTH ST
DAYTON OH 45402 2911



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 15, 2010

CERTIFIED MAIL

Mr. Garry Myers
Le-O-Na Falls Mobile Home Park
8112 State Route 55
Ludlow Falls, OH 45339


**RE: NOTICE OF VIOLATION – Le-O-Na Falls Mobile Home Park WWTP
8112 State Route 55, Miami County
NPDES Permit 1PV00123*AD/OH0133698**

Dear Mr. Myers,

As the owner of Le-O-Na Falls MHP, you have failed to meet the requirements of the NPDES permit Schedule of Compliance. The Schedule of Compliance requires the submittal of a permit to install (PTI) for wastewater improvements by March 1, 2004. Initiation of construction of the improvements approved through the PTI was to commence by October 1, 2004. Completion of construction of the improvements was due by June 1, 2005, with final compliance with effluent limits expected by June 1, 2005. Clearly none of these items have been completed. In addition, no progress has been reported by this facility with regards to this schedule. In addition, a review of the operating reports indicates violations of the NPDES permit (May 2009 to November 2009). Effluent limitation violations are listed on the following page.

This matter has been forwarded to Ohio EPA's Legal Services for enforcement action. If you have any questions, I can be reached at (937) 285-6109.

Sincerely,



~~Joe Miller~~
Division of Surface Water
Compliance and Enforcement

cc: Miami County Health Department

Le-O-Na Falls MHP Number Effluent Violations May 2009 to November 2009

Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
80082	CBOD 5 day	30D Conc	10	13.	6/1/2009
00400	pH	1D Conc	6.5	6.36	6/12/2009
00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	6.3	8/1/2009
80082	CBOD 5 day	30D Conc	10	12.	8/1/2009
00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	6.3	8/8/2009
50060	Chlorine, Total Residual	1D Conc	0.019	.09	8/14/2009