



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PT0011020090508

MIAMI

PIQUA SPRINGCREEK ELEM SCH

MILLER, JOSEPH

2009/05/08

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

May 11, 2009

Richard A. Hanes, Superintendent
Piqua City Schools
719 East Ash Street
Piqua, OH 45356

NOTICE OF VIOLATION

**RE: Spring Creek Primary School Wastewater Treatment Plant
Compliance Evaluation Inspection
NPDES Permit 1PT00110*BD/OH0133761
Spring Creek Township, Miami County**

Dear Superintendent Hanes,

On April 23, 2009, I conducted an inspection at the above referenced wastewater treatment works. This inspection was conducted to determine compliance with NPDES permit 1PT00110*BD.

Effluent limitation and frequency violations continue to be problematic at this facility. The operating report (eDMR) for March 2009 data has not been submitted. Part III, Item 4 of your NPDES permit requires the eDMR submittal for each month by the 20th of the following month.


Provide a response to the items noted under "Items Requiring a Response" heading of the inspection report by **May 29, 2009**. Your response should include dates, either actual or proposed, for completion of actions.

If you have any questions, I can be reached at (937) 285-6109.

Sincerely,

Joe Miller
Division of Surface Water
Compliance and Enforcement

CC: Johnny Shingleton, Operator
Molly Hay, Principal
Miami County Health Department





Items Requiring a Response

1. Operating Report (eDMR) – The March 2009 operating report has not been submitted. The eDMR needs to be submitted as soon as possible.
2. Effluent Violations – Ohio EPA has reviewed the submitted self monitoring reports for the period of November 2008 to March 2009. Effluent limitation violations and frequency violations were noted during this period of time. Provide the reasons for the listed violations, as well as a description of the action taken or proposed to prevent further violations. Future violations need to be reported as per your NPDES Permit. See Part III, Item 12 of your NPDES Permit, entitled “Non-Compliance Notification”.

Item Not Requiring a Response

Miami County Sanitary Engineering has received economic stimulus funding for completion of the sanitary sewer project to provide service to the Village of Fletcher. This sewer will also provide service to the Spring Creek Primary School. Until the project is completed and a tie-in the sanitary sewer is made, the wastewater treatment plant is expected to be operated in compliance with the NPDES permit. The wastewater treatment plant will need to be removed or properly abandoned at that time as well. Provide notification to this office when the sanitary sewer connection is completed. Construction on this project is expected to begin later this year.



Permit # : 1PT00110*BD
 NPDES # : OH0133761





State of Ohio Environmental Protection Agency
 Southwest District Office

NPDES Compliance Inspection Report
 Semi-Public Sewage Disposal Inspection Form

| Section A: National Data System Coding | | | | | |
|--|-----------|----------------|-----------------|-----------|---------------|
| Permit # | NPDES# | Month/Day/Year | Inspection Type | Inspector | Facility Type |
| 1PT00110*BD | OH0133761 | 4/23/2009 | C | S | 2 |

| Section B: Facility Data | | |
|--|-----------------|------------------------|
| Name and Location of Facility Inspected | Entry Time | Permit Effective Date |
| Piqua Springcreek Elementary 145 East State Route 36 Piqua, OH 45356 | 2:00 PM | June 1, 2008 |
| | Exit Time | Permit Expiration Date |
| | 2:10 PM | May 31, 2013 |
| Name(s) and Title(s) of On-Site Representatives | Phone Number(s) | |
| N/A | | |
| Name(s), Address and Title(s) of Operator of Record | Phone Number(s) | |
| Johnny Shingleton | 937-477-5742 | |
| Name, Address and Title of Responsible Official | Phone Number | |
| Piqua City Schools 719 East Ash Street Piqua, OH 45356 | 937-773-4321 | |

| Ohio EPA Inspector | Ohio EPA Reviewer |
|---|--|
|  Joe Miller Division of Surface Water Southwest District Office |  Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office |
| Date 5/11/09 | Date 5/11/09 |



| | |
|--|--|
| Average Daily Design Flow: | 10,000 Gallons/Day |
| Plant Serves: | Elementary School |
| Average Daily Flow: (Period of Review): | 1,750 GPD (November 2008 to March 2009) |
| Method of flow monitoring: | Pump hours |
| Type of alarms for plant: | Audio/visual |

Pretreatment

Type of Pretreatment: **Trash Trap**
 Does the Trash Trap need pumped: **Unknown**
 Maintenance of pretreatment components is: **Satisfactory**

Comments/Status:

**Secondary Treatment
(Aeration)**

Color of sludge: **Light Brown**
 Quality of Sludge: **Thin**
 Foam: **None present**
 Odor: **No objectionable odor present**

| | Yes | No | | Yes | No |
|----------------------------|-------------------------------------|--------------------------|------------------------|-------------------------------------|-------------------------------------|
| Aeration is taking place | <input checked="" type="checkbox"/> | <input type="checkbox"/> | Plant is septic | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Blowers are operating | <input checked="" type="checkbox"/> | <input type="checkbox"/> | Blowers are on a timer | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Skimmers are operating | <input checked="" type="checkbox"/> | <input type="checkbox"/> | Plant is flooded | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Diffusers are operating | <input checked="" type="checkbox"/> | <input type="checkbox"/> | Grating is present | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Sludge return is operating | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |

Maintenance of aerating equipment is... **Satisfactory**

Comments/Status:

**Secondary Treatment
(Settling)**

Clarity: **Clear**
 Condition of Weir: **Clean**
 Weir is level: **Yes**
 Effluent in weir: **None**
 Clarifier walls need scraped: **Unknown**

Overall maintenance of settling components is: **Satisfactory**

Comments/Status:



Tertiary Treatment

| | Yes | No | | Yes | No |
|-----------------------------------|-------------------------------------|-------------------------------------|------------------------|-------------------------------------|-------------------------------------|
| Surface sand Filters: Slow | <input checked="" type="checkbox"/> | <input type="checkbox"/> | Subsurface | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| Distribution box operating | <input checked="" type="checkbox"/> | <input type="checkbox"/> | Beds alternated | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Are filters ponding/flooding | <input type="checkbox"/> | <input checked="" type="checkbox"/> | Beds raked | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| Sand filters overgrown | <input type="checkbox"/> | <input checked="" type="checkbox"/> | Chlorination present | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| UV present | <input type="checkbox"/> | <input checked="" type="checkbox"/> | Dechlorination present | <input type="checkbox"/> | <input checked="" type="checkbox"/> |

Overall maintenance of components is: **Satisfactory**

Comments/Status:

Sludge Handling/Storage Disposal

Hauler name: Sludge not reported as hauled
 Disposal Site: POTW
 Sludge wasted from: Sludge holding tank
 How often is sludge wasted: sludge not wasted during period of review
 Sludge drying beds: **No** Sludge holding tank: **Yes**

Overall maintenance of components is: **Satisfactory**

Comments/Status:

Plant Discharge

Discharge point is: **Field tile**
 Name of discharge point: **Unnamed tributary of Garbry Creek**
 Discharge is visible: **No** Quality of Effluent: **Clear**

Comments/Status:

Operating reports not received for March 2009. Frequency violations and effluent limitation violations noted during period of review.



Effluent Limitation Violations November 2008 to March 2009

| Reporting Period | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|------------------|----------------|-------------------------|------------|-------|----------------|----------------|
| November 2008 | 00530 | Total Suspended Solids | 30D Conc | 12 | 21. | 11/1/2008 |
| November 2008 | 00610 | Nitrogen, Ammonia (NH3) | 30D Conc | 3.0 | 23. | 11/1/2008 |
| November 2008 | 80082 | CBOD 5 day | 30D Conc | 10 | 17. | 11/1/2008 |
| November 2008 | 00530 | Total Suspended Solids | 7D Conc | 18 | 21. | 11/22/2008 |
| November 2008 | 00610 | Nitrogen, Ammonia (NH3) | 7D Conc | 4.5 | 23. | 11/22/2008 |
| November 2008 | 80082 | CBOD 5 day | 7D Conc | 15 | 17. | 11/22/2008 |

Effluent Frequency Violations November 2008 to March 2009

| Reporting Period | Reporting Code | Parameter | Sample Frequency | Expected | Reported | Violation Date |
|------------------|----------------|---------------------|------------------|----------|----------|----------------|
| November 2008 | 00010 | Water Temperature | 1/Week | 1 | 0 | 11/01/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/01/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/01/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/01/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/01/2008 |
| November 2008 | 00400 | pH | 1/2Weeks | 1 | 0 | 11/01/2008 |
| November 2008 | 00300 | Dissolved Oxygen | 1/Week | 1 | 0 | 11/01/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/02/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/02/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/02/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/02/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/03/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/03/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/03/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/03/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/04/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/04/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/04/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/04/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/05/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/05/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/05/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/05/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/06/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/06/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/06/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/06/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/07/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/07/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/07/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/07/2008 |
| November 2008 | 00010 | Water Temperature | 1/Week | 1 | 0 | 11/08/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/08/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/08/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/08/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/08/2008 |




| | | | | | | |
|---------------|-------|---------------------|----------|---|---|------------|
| November 2008 | 00300 | Dissolved Oxygen | 1/Week | 1 | 0 | 11/08/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/09/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/09/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/09/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/09/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/10/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/10/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/10/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/10/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/11/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/11/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/11/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/11/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/12/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/12/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/12/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/12/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/13/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/13/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/13/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/13/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/14/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/14/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/14/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/14/2008 |
| November 2008 | 00010 | Water Temperature | 1/Week | 1 | 0 | 11/15/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/15/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/15/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/15/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/15/2008 |
| November 2008 | 00400 | pH | 1/2Weeks | 1 | 0 | 11/15/2008 |
| November 2008 | 00300 | Dissolved Oxygen | 1/Week | 1 | 0 | 11/15/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/16/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/16/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/16/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/16/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/17/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/17/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/17/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/17/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/18/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/18/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/18/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/18/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/19/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/19/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/19/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/19/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/20/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/20/2008 |



Permit # : 1PT00110*BD
NPDES #: OH0133761

| | | | | | | |
|---------------|-------|---------------------|--------|---|---|------------|
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/20/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/20/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/21/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/21/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/21/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/21/2008 |
| November 2008 | 00010 | Water Temperature | 1/Week | 1 | 0 | 11/22/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/22/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/22/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/22/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/22/2008 |
| November 2008 | 00300 | Dissolved Oxygen | 1/Week | 1 | 0 | 11/22/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/23/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/23/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/23/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/23/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/24/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/24/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/24/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/24/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/25/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/25/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/25/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/25/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/26/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/26/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/26/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/26/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/27/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/27/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/27/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/27/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/28/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/28/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/28/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/28/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/29/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/29/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/29/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/29/2008 |
| November 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 11/30/2008 |
| November 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 11/30/2008 |
| November 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 11/30/2008 |
| November 2008 | 50050 | Flow Rate | 1/Day | 1 | 0 | 11/30/2008 |
| December 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 12/17/2008 |
| December 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 12/17/2008 |
| December 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 12/17/2008 |
| December 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 12/19/2008 |
| December 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 12/19/2008 |
| December 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 12/19/2008 |



| | | | | | | |
|---------------|-------|---------------------|-------|---|---|------------|
| December 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 12/22/2008 |
| December 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 12/22/2008 |
| December 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 12/22/2008 |
| December 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 12/23/2008 |
| December 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 12/23/2008 |
| December 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 12/23/2008 |
| December 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 12/24/2008 |
| December 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 12/24/2008 |
| December 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 12/24/2008 |
| December 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 12/26/2008 |
| December 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 12/26/2008 |
| December 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 12/26/2008 |
| December 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 12/29/2008 |
| December 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 12/29/2008 |
| December 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 12/29/2008 |
| December 2008 | 00083 | Color, Severity | 1/Day | 1 | 0 | 12/30/2008 |
| December 2008 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 12/30/2008 |
| December 2008 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 12/30/2008 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/02/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/02/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/02/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/03/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/03/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/03/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/05/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/05/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/05/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/06/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/06/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/06/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/07/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/07/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/07/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/08/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/08/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/08/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/09/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/09/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/09/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/10/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/10/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/10/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/11/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/11/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/11/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/15/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/15/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/15/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/16/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/16/2009 |



Permit # : 1PT00110*BD
NPDES #: OH0133761

| | | | | | | |
|--------------|-------|---------------------|-------|---|---|------------|
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/16/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/17/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/17/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/17/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/20/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/20/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/20/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/24/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/24/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/24/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/28/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/28/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/28/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/29/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/29/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/29/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/30/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/30/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/30/2009 |
| January 2009 | 00083 | Color, Severity | 1/Day | 1 | 0 | 01/31/2009 |
| January 2009 | 01330 | Odor, Severity | 1/Day | 1 | 0 | 01/31/2009 |
| January 2009 | 01350 | Turbidity, Severity | 1/Day | 1 | 0 | 01/31/2009 |

