


**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



February 17, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

CERTIFIED MAIL

9171082133393715014695

Dan George
Telesis Technologies Inc
28181 River Drive,
Circleville, OH 43113

Pickaway County
Telesis Technologies Inc
Non-Transient Non-Community PWS
PWS ID: OH6539812
Facility ID: 6557240

Subject: Violation of Maximum Contaminant Level for ARSENIC

Telesis Technologies Inc is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. Telesis Technologies Inc exceeded the MCL for arsenic during the following time periods:

<u>Time Period</u>	<u>Arsenic Running Annual Average</u>
January 1 to March 31, 2011	0.018 mg/L
April 1 to June 30, 2011	0.017 mg/L
July 1 to September 30, 2011	0.015 mg/L
October 1 to December 31, 2011	0.011 mg/L

To address the MCL violations, Telesis Technologies Inc is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the mailing address below within ten days after issuance.
3. Continue to perform quarterly monitoring for ARSENIC during each calendar quarter.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to additional enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto

Kathleen Pinto
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form

cc: Pickaway County Health Department

50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 644 3020
614 | 644 3184 (fax)
www.epa.ohio.gov

DRINKING WATER NOTICE

Telesis Technologies Inc Has Levels of ARSENIC above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. . The standard for ARSENIC is 0.010 MG/L. Telesis Technologies exceeded the MCL during the following time periods:

<u>Time Period</u>	<u>Arsenic Running Annual Average</u>
January 1 to March 31, 2011	0.018 mg/L
April 1 to June 30, 2011	0.017 mg/L
July 1 to September 30, 2011	0.015 mg/L
October 1 to December 31, 2011	0.011 mg/L

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____.

Phone Number: _____.

Mailing Address: _____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: _____

PWSID: OH6539812 Facility ID: 6557240

Monitoring Period: Fourth Quarter of 2011

DRINKING WATER NOTICE

Telesis Technologies Inc Has Levels of ARSENIC above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. . The standard for ARSENIC is 0.010 MG/L. Telesis Technologies exceeded the MCL during the following time periods:

<u>Time Period</u>	<u>Arsenic Running Annual Average</u>
January 1 to March 31, 2011	0.018 mg/L
April 1 to June 30, 2011	0.017 mg/L
July 1 to September 30, 2011	0.015 mg/L
October 1 to December 31, 2011	0.011 mg/L

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____.

Phone Number: _____.

Mailing Address: _____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: _____

PWSID: OH6539812 Facility ID: 6557240

Monitoring Period: Fourth Quarter of 2011