


**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



February 17, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

CERTIFIED MAIL

9171082133393715014688

Larry Crisler
Greenlawn Condos
3330 Party Lane,
Springfield, OH 45504

Clark County
Greenlawn Condos
Community PWS
PWS ID: OH1204912
Facility ID: 1253249

Subject: Violation of Maximum Contaminant Level for ARSENIC

Greenlawn Condos is in violation for exceeding the maximum contaminant level (MCL) standard of 0.010 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-11 for ARSENIC. Compliance with the MCL is based on a running annual average. The annual average for ARSENIC during the Fourth Quarter of 2011 time period is 0.012 MG/L.

To address the MCL violation, Greenlawn Condos is required to take the following actions:

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the mailing address below within ten days after issuance.
3. Perform quarterly monitoring for ARSENIC during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any previously issued enforcement action.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to additional enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Kathleen Pinto

Kathleen Pinto
Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form
cc: Clark County Health Department

DRINKING WATER NOTICE

Greenlawn Condos Has Levels of ARSENIC above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. The average level of ARSENIC over the last four quarters was 0.012 MG/L. The standard for ARSENIC is 0.010 MG/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____.

Phone Number: _____.

Mailing Address: _____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: _____

PWSID: OH1204912 Facility ID: 1253249

Monitoring Period: Fourth Quarter of 2011

DRINKING WATER NOTICE

Greenlawn Condos Has Levels of ARSENIC above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for ARSENIC. The average level of ARSENIC over the last four quarters was 0.012 MG/L. The standard for ARSENIC is 0.010 MG/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the necessary steps to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: _____

Phone Number: _____

Mailing Address: _____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: _____

PWSID: OH1204912 Facility ID: 1253249

Monitoring Period: Fourth Quarter of 2011