

Walbridge, Matt

From: Tom Saldoff <TSaldoff@anchorfab.com>
Sent: Monday, August 15, 2011 11:24 AM
To: Walbridge, Matt
Cc: Charlotte Collins
Subject: RE: Discharge Monitoring Reports

Thanks for the heads up and the procedural clarification. We've re-submitted the June data. Hope that gets us back on track...

Regards,

Tom

From: Walbridge, Matt [mailto:Matt.Walbridge@epa.state.oh.us]
Sent: Friday, August 12, 2011 4:48 PM
To: Tom Saldoff
Subject: Discharge Monitoring Reports

Mr. Saldoff -

You were recently notified of your failure to submit a discharge monitoring report (DMR) for June 2011. In reviewing your recent DMR submittals, I noted that you are typically entering either the 'AC' (plant not discharging) or 'AD' (plant not normally staffed) for each day of the month. Please note that your monitoring frequency is once per month so **IF** there is a discharge during the month, only one entry per parameter is needed.

If there is no discharge during the whole month, you should instead check the 'no discharge for the month' box of the e-DMR report. No codes need to be entered for each day of the month.

If there is a discharge during the month, you must report the flow value and that value cannot be zero. The monitoring you do must be on what is discharged that day and the discharge volume must be reported.

Please submit the missing report for June and ensure all future monitoring data also includes a legitimate flow value that reflects the amount of discharge on the day of sampling.

If you have any questions, please call or e-mail me.

Sincerely,

Matt Walbridge

(937) 285-6095

