



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 23, 2009

Mr. Bill Huston, CHMM
Behr Dayton Thermal Products
1600 Webster Street
Dayton, Ohio

Re: Montgomery County, Behr Dayton Thermal Products, Notice of Violation

Dear Mr. Huston:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of January 2009 through May 2009 for Behr Dayton Thermal Products. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0009199; OEPA Permit # 11N00089*FD). The specific instances of noncompliance are as follows:

| Effluent Violations | | | | | | |
|---------------------|---------|------------------------|------------|-------|----------------|----------------|
| Reporting Period | Station | Parameter | Limit Type | Limit | Reported Value | Violation Date |
| May 2009 | 001 | Trichloroethylene | Daily Conc | 5.0 | 23 | 5/21/2009 |
| May 2009 | 001 | 1,2-Cis-Dichloroethene | Daily Conc | 5.0 | 9.3 | 5/21/2009 |

The above referenced violations were reported as required by the NPDES Permit as detailed in Part III. 12 titled "Noncompliance Notification". Responses for the above referenced violations have been received and an additional response is not required at this time. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Mr. Bill Huston, CHMM
June 23, 2009
Page 2

If you have any questions regarding this matter please feel free to contact me at (937) 285-6107 or via email at: Robert.Ostendorf@epa.state.oh.us.

Sincerely,

A handwritten signature in cursive script that reads "Bob Ostendorf Jr." with a stylized flourish at the end.

Bob Ostendorf Jr.
Division of Surface Water
Permits Section

cc: Mr. Gary M. Stanczuk, Chrysler