Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 8, 2011

Mr. Bill Huston, CHMM
Behr Dayton Thermal Products
1600 Webster Street
Dayton, Ohio 45404

Re: Montgomery County, Behr Dayton Thermal Products, NPDES Permit Violations

Dear Mr. Huston:

The Ohio EPA has completed a compliance evaluation of the Data Monitoring Reports (DMR) covering the months of July through December 2010 for the Behr Dayton Thermal Products. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0009199; OEPA Permit # 1IN00089*FD). The specific instances of noncompliance are as follows:

Effluent Limit Violations

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2010	pH, Minimum	Daily Conc	6.5	6.4	9/22/2010
December 2010	TSS	Monthly Conc	30	55	12/1/2010
December 2010	TSS	Daily Conc	45	55	12/14/2010

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is required at this time.

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,

Bob Ostendorf Jr.
Division of Surface Water
Permit Section

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov