



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PC0000020110204

MONTGOME BROOKVILLE WWTP

OSTENDORF, ROBE 2011/02/04

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director





**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 4, 2011

Mr. John Wright
City of Brookville
301 Sycamore Street
Brookville, Ohio 45309

Re: Montgomery County, City of Brookville WWTP, NPDES Permit Violations

Dear Mr. Wright:

The Ohio EPA has completed a compliance evaluation of the Data Monitoring Reports (DMR) covering the months of October through December 2010 for the City of Brookville WWTP. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0020605; OEPA Permit # 1PC00000*ID). The specific instances of noncompliance are as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
November 2010	Ammonia	Weekly Conc	3.8	7.3	11/22/2010
November 2010	Ammonia	Weekly Qty	17.3	20.9	11/22/2010

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is required at this time.

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,

Bob Ostendorf Jr.
Division of Surface Water
Permit Section

