



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PC0000020110614

MONTGOME BROOKVILLE WWTP

OSTENDORF, ROBE 2011/06/14

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer





Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 14, 2011

Mr. John Wright
City of Brookville
301 Sycamore Street
Brookville, Ohio 45309

Re: Montgomery County, City of Brookville WWTP, NPDES Permit Violations

Dear Mr. Wright:

The Ohio EPA has completed a compliance evaluation of the Data Monitoring Reports (DMR) covering the months of January through April 2011 for the City of Brookville WWTP. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0020605; OEPA Permit # 1PC00000*ID). The specific instances of noncompliance are as follows:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
April 2011	TSS	Monthly Qty	54.6	70.1	4/1/2011
April 2011	TSS	Weekly Qty	81.9	95.3	4/15/2011
April 2011	TSS	Weekly Qty	81.9	116.7	4/22/2011

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations.

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,

Bob Ostendorf Jr.
Division of Surface Water
Permit Section