



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PD0000120070427

MONTGOME ENGLEWOOD WWTP

MILLER, JOSEPH 2007/04/27

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer



Englewood
correspondence



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

April 27, 2007

Mayor and Council
City of Englewood
333 West National Road
Englewood, OH 45322

RE: NOTICE OF VIOLATION
City of Englewood Wastewater Treatment Plant Effluent Limit Violations
NPDES 1PD00001*LD/OH0025011, Englewood, Montgomery County

Ladies and Gentlemen,

Ohio EPA has reviewed your monthly operating reports for the period of July 2006 to January 2007 for the above referenced facility. Our review indicates violation of your NPDES permit (1PD00001*LD/OH0025011). The specific instances of noncompliance are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
July 2006	001	Chlorine, Total Residual	1D Conc	0.038	0.32	7/19/2006
September 2006	001	Total Suspended Solids	7D Qty	426	451.97	9/8/2006
September 2006	001	Dissolved Oxygen	1D Conc	6.0	5.5	9/12/2006
October 2006	001	Fecal Coliform	30D Conc	1000	1582.62	10/1/2006
October 2006	001	Fecal Coliform	7D Conc	2000	3544.52	10/15/2006

Please inform this office, in writing, as to the reasons for the aforementioned violations, as well as a description of the action taken or proposed to prevent further violations. Your response should include the dates, either actual or proposed, for completion of actions. Future violations need to be reported as per your NPDES Permit. See Part III, Item 12 of your NPDES Permit, entitled "Non-Compliance Notification".

A response is requested by May 14, 2007. Should you have any questions, I can be reached at (937) 285-6109.

Sincerely,

Joe Miller
Division of Surface Water

CC: Vernon Brown, WWTP Superintendent



-

.

.