



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049



\*1PB0001020100727\*

MONTGOME FARMERSVILLE WWTP

OSTENDORF, ROBE 2010/07/27

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

*Ohio EPA is an Equal Opportunity Employer*



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korfeski, Director

August 6, 2010

Mr. Tom Sears  
Village Administrator  
Village of Farmersville  
117 East Walnut  
Farmersville, Ohio 45325

Re: Montgomery County, Village of Farmersville, Notice of Violation

Dear Mr. Sears:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of January 2010 through June 2010 for the Village of Farmersville. The evaluation indicates a violation of the conditions of your NPDES Permit (NPDES Permit # OH0020770; OEPA Permit # 1PB00010\*HD). The specific instance of noncompliance is as follows:

Effluent Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2010	Oil and Grease	Daily	10.0	16.6	6/10/2010

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

The Ohio EPA is in receipt of the notification of the effluent violation per Part III of permit 1PB00010\*HD. The explanation given with the notification is satisfactory and an additional response is not required. If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at [Robert.Ostendorf@epa.state.oh.us](mailto:Robert.Ostendorf@epa.state.oh.us).

Sincerely,

Bob Ostendorf Jr.  
Division of Surface Water  
Permit Section

