



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



11C0000820081230

MONTGOME GENERAL MOTORS CORP MORaine UTILITY
SERVICES *

OSTENDORF, ROBE 2008/12/30

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer





State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 30, 2008

Ms. Holly Hanes
General Motors Corporation – Moraine Utilities Services
2601 West Stroop Road
Moraine, Ohio 45439

Re: Montgomery County, General Motors Corporation – Moraine Utilities Services,
NPDES Permit Violations

Dear Ms. Hanes:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of August 2007 through December 2008 for General Motors Corporation – Moraine Utilities Services. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0009431; OEPA Permit # 11C00008*ID). The specific instances of noncompliance are as follows:

Effluent Limit Violations						
Reporting Period	Outfall	Parameter	Limit Type	Limit	Reported Value	Date of Violation
June 2008	001	TSS	Monthly Qty	86.5	135	06/01/2008
June 2008	001	TSS	Daily Qty	129	269	06/04/2008
June 2008	001	pH	Daily Conc	6.5	6.0	06/04/2008
December 2007	002	TSS	Monthly Conc	30	42	12/01/2007
December 2007	002	TSS	Monthly Qty	142	217	12/01/2007
December 2007	002	TSS	Daily Conc	45	71	12/20/2007
December 2007	002	TSS	Daily Qty	213	375	12/20/2007
June 2008	002	TSS	Monthly Qty	142	165	06/01/2008
June 2008	002	TSS	Daily Qty	213	308	06/04/2008
June 2008	002	pH	Daily Conc	6.5	6	06/04/2008


The Ohio EPA has received reports regarding the above referenced violations and a response to this Notice of Violation is not required. Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES

Ms. Holly Hanes
December 30, 2008
Page 2

Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,

A handwritten signature in cursive script that reads "Bob Ostendorf Jr." with a stylized flourish at the end.

Bob Ostendorf Jr.
Division of Surface Water
Permit Section