



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1PT0010720090923

MONTGOME JEFFERSON TWP JR HIGH ELEM

OSTENDORF, ROBE 2009/09/23

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 23, 2009

Dr. Gates, Superintendent
Jefferson Township Local Schools
2625 South Union Road
Dayton, Ohio 45418

Re: Montgomery County, Jefferson Township Local Schools, NPDES Permit Violations

Dear Dr. Gates:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of January 2009 through August 2009 for Jefferson Township Local Schools. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0132250; OEPA Permit # 1PT00107*BD). The specific instances of noncompliance are as follows:

Reporting Period	Parameter	Effluent Violations		Reported Value	Date of Violation
		Limit Type	Limit		
May 2009	Chlorine	Daily	0.038	0.1	5/7/2009
May 2009	Fecal Coliform	Weekly	2000	2000	5/8/2009

The Ohio EPA has received a response for the violations which occurred in May of 2009 and no further response is required at this time. Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,

Bob Ostendorf Jr.
Division of Surface Water
Permit Section

Cc: Mr. Terry Morris

