



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049



\*1PT0010720081230\*

MONTGOME JEFFERSON TWP JR HIGH ELEM

OSTENDORF, ROBE 2008/12/30

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 30, 2008

Dr. Norris Brown, Superintendent  
Jefferson Township Local Schools  
2625 South Union Road  
Dayton, Ohio 45418

Re: Montgomery County, Jefferson Township Local Schools, NPDES Permit Violations

Dear Mr. Brown:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of March 2008 through December 2008 for Jefferson Township Local Schools. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0132250; OEPA Permit # 1PT00107\*BD). The specific instances of noncompliance are as follows:

Effluent Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Date of Violation
April 2008	pH	Daily	6.5	6.03	4/3/2008


Frequency / Reporting Violations					
Reporting Period	Parameter	Limit Type	Expected	Reported	Date of Violation
May 2008	Dissolved Oxygen	1/Week	1	0	05/08/2008

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations. Your response should include the dates, either actual or proposed, for completion of said actions. Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Dr. Norris Brown  
December 30, 2008  
Page 2

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at [Robert.Ostendorf@epa.state.oh.us](mailto:Robert.Ostendorf@epa.state.oh.us).

Sincerely,

A handwritten signature in cursive script that reads "Bob Ostendorf Jr." The signature is written in black ink and is positioned above the typed name.

Bob Ostendorf Jr.  
Division of Surface Water  
Permit Section