



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049



\*1PL0000220110613\*

MONTGOME MONTGOMERY CO WESTERN REGIONAL WWTP · OSTENDORF, ROBE 2011/06/13

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director





Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 13, 2011

Montgomery County Board of Commissioners  
451 West Third Street  
Dayton, Ohio 45402

Re: Montgomery County, Montgomery County Western Regional WWTP, Notice of Violation

Ladies and Gentlemen:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of July 2010 through April 2011 for the Montgomery County Western Regional WWTP. The evaluation indicates a violations of the conditions of your NPDES Permit (NPDES Permit # OH0026638; OEPA Permit # 1PL00002\*MD). The specific instance of noncompliance is as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2011	TSS	Monthly Conc	12	24	2/1/2011
February 2011	TSS	Weekly Conc	18	76	2/1/2011
February 2011	TSS	Monthly Qty	909	1453	2/1/2011
February 2011	TSS	Weekly Qty	1363	4621	2/1/2011
February 2011	CBOD	Monthly Conc	10	20	2/1/2011
February 2011	CBOD	Weekly Conc	15	35	2/1/2011
February 2011	CBOD	Monthly Qty	757	1233	2/1/2011
February 2011	CBOD	Weekly Qty	1136	2104	2/1/2011
February 2011	CBOD	Weekly Conc	15	26	2/15/2011
February 2011	CBOD	Weekly Qty	1136	1324	2/15/2011
April 2011	TSS	Weekly Qty	1363	2223	4/22/2011

Effluent violations of Part III, Item 11 of permit PL00002 MD			
Bypass Events			
Date(s)	Duration	Treatment Unit(s) Bypassed	Reason Cited
2/21/11 – 2/22/11	8 hrs	Tertiary Filters	Excessive flow due to rain event.
2/25/11 – 2/26/11	24 hrs	Tertiary Filters	Excessive flow due to rain event.
2/28/11 – 3/1/11	12 hrs	Tertiary Filters	Excessive flow due to rain event.
3/4/11 – 3/7/11	58 hrs	Tertiary Filters	Excessive flow due to rain event.
3/9/11 – 3/11/11	44.1 hrs	Tertiary Filters	Excessive flow due to rain event.
3/12/11 – 3/13/11	22 hrs	Tertiary Filters	Excessive flow due to rain event.
4/19/11 – 4/29/11	9 days 19 hrs	Tertiary Filters	Excessive flow due to rain event.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is required at this time.

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at [Robert.Ostendorf@epa.state.oh.us](mailto:Robert.Ostendorf@epa.state.oh.us).

Sincerely,

Bob Ostendorf Jr.  
 Division of Surface Water  
 Permit Section