



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049



\*1PB0002120090602\*

MONTGOME NEW LEBANON STP

OSTENDORF, ROBE 2009/06/02

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

*Ohio EPA is an Equal Opportunity Employer*



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street  
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 2, 2009

Mr. George Markus  
Municipal Manager  
Municipality of New Lebanon  
198 South Clayton Road  
New Lebanon, Ohio 45345

Re: Montgomery County, Municipality of New Lebanon, NPDES Permit Violations

Dear Mr. Markus:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of October 2008 through May 2009 for the Municipality of New Lebanon. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0026697; OEPA Permit # 1PB00021\*HD). The specific instances of noncompliance are as follows:

Effluent Limit Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2009	pH	Daily Maximum	9.0	11.0	2/9/2009
February 2009	pH	Daily Maximum	9.0	10.2	2/10/2009
February 2009	pH	Daily Maximum	9.0	10.8	2/11/2009
February 2009	pH	Daily Maximum	9.0	9.5	2/12/2009
February 2009	pH	Daily Maximum	9.0	9.2	2/13/2009
February 2009	pH	Daily Maximum	9.0	9.7	2/17/2009
February 2009	pH	Daily Maximum	9.0	10.1	2/18/2009
February 2009	pH	Daily Maximum	9.0	10.2	2/19/2009
February 2009	pH	Daily Maximum	9.0	10.1	2/20/2009


Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Mr. George Markus  
June 2, 2009  
Page 2

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent further violations. Your response should include the dates, either actual or proposed, for completion of said actions. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at [Robert.Ostendorf@epa.state.oh.us](mailto:Robert.Ostendorf@epa.state.oh.us).

Sincerely,



Bob Ostendorf Jr.  
Division of Surface Water  
Permit Section

Cc: Matt Fraley, WWTP Operator