



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049



1IX0011020090128

MONTGOME OAKWOOD WATER SOFTENING PLANT NO 2 | OSTENDORF, ROBE 2009/01/28

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ohio EPA is an Equal Opportunity Employer



State of Ohio Environmental Protection Agency

Southwest District Office

401 East Fifth Street
Dayton, Ohio 45402-2911

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

January 28, 2009

Mr. Norbert Klopsch
City of Oakwood
30 Park Avenue
Oakwood, Ohio 45419

Re: Montgomery County, Oakwood Water Softening Plant 2, NPDES Permit Violations

Dear Mr. Klopsch:

The Ohio EPA has completed a compliance evaluation of the Monthly Operating Reports covering the months of January 2005 through December 2008 for Oakwood Water Softening Plant 2. The evaluation indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0105449; OEPA Permit # 1IX00110*BD). The specific instances of noncompliance are as follows:

Effluent Violations					
Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2005	pH	Daily Conc	6.5	6.28	2/14/2005
December 2008	pH	Daily Conc	6.5	6.4	12/10/2008


This office has received written notification as to the reasons for the above referenced violation, as well as the actions taken or proposed to prevent any further violations. Future violations must be reported as required by the NPDES Permit as detailed in Part III.12 titled "Noncompliance Notification."

Please be advised that failure to comply with the effluent limitations, monitoring, or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Mr. Norbert Klopsch
January 28, 2009
Page 2

If you have any questions or concerns regarding this matter please feel free to contact me at (937) 285-6107 or via email at Robert.Ostendorf@epa.state.oh.us.

Sincerely,

A handwritten signature in black ink, appearing to read "Bob Ostendorf Jr.", with a stylized flourish at the end.

Bob Ostendorf Jr.
Division of Surface Water
Permit Section