



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PD0002020100716

MONTGOME TRI-CITIES NORTH REGIONAL WW AUTHORITY BURNS, LAUREN 2010/07/16



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

July 16, 2010

Mr. David Heckler
TCA General Manager
Tri-Cities North Regional WWTP
3777 Old Needmore Road
Dayton, Ohio 45424

**RE: Tri Cities North Regional WWTP, NPDES Permit 1PD00020*ID / OH0049646,
Notice of Violation.**

Dear Mr. Heckler:

Ohio EPA has reviewed your Electronic Discharge Monitoring Reports (EDMR's) for the period of January 1, 2010 through May 31, 2010. During this time period Tri Cities reported one final effluent violation.

During the second week of May, 2010, a weekly average Ammonia of 2.46 mg/l was recorded. The weekly average permit limit is 2.3 mg/l. In follow-up a Non-compliance Notification form was e-mailed to the agency on May 15, 2010. This follow-up response satisfies the notification requirements for this violation. No additional information is needed at this time.

If you have any questions, please call me at (937) 285 – 6097.

Sincerely,

Joseph Reynolds
Division of Surface Water

cc: Joseph Hart, Tri Cities Operator

