Ohio | Environmental Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

1PP0000520100311

PREBLE	HUESTON WOODS STATE PARK LODGE & CABINS WWTP	WARE, MAUREEN	2010/03/11

50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 644 3020
614 | 644 3184 (fax)
www.epa.ohio.gov

File: Preble
Hueston Woods
Beach/Marina &
Lodge/Cabin
Sewerage

Ohio | Environmental Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

March 11, 2010

CERTIFIED MAIL

Lonnie Snow, Regional Manager
Hueston Wood State Park
6301 Park Office Rd.
College Corner, Ohio 45003

RE: Notice of Violation for
Hueston Woods Beach/Marina NPDES 1PP00002 and
Lodge/Cabin NPDES 1PP00005

Dear Mr. Snow:

A review of your self-monitoring reports for the NPDES permit 1PP00002 and 1PP00005 for the Hueston Woods Beach/Marina WWTP and the Lodge/Cabin WWTP covering the months of March 2008 through January 2010 indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies for 1PP00002 were as follows:

Numerical Violations

Date	Station	Parameter	Code	Permit Requirements	Reported
6/1/2008	001	Ammonia	00610	2.0 mg/l	3.25 mg/l
6/1/2008	001	Ammonia	00610	3.0 mg/l	6.5 mg/l
6/1/2008	001	Ammonia	00610	0.57 kg/day	0.69 kg/day
7/1/2008	001	Ammonia	00610	2.0 mg/l	12.85 mg/l
7/1/2008	001	Ammonia	00610	3.0 mg/l	16.0 mg/l
7/1/2008	001	Ammonia	00610	0.38 kg/day	1.83 kg/day
7/1/2008	001	Ammonia	00610	0.57 kg/day	2.12 kg/day
7/8/2008	001	Susp. Solids	00530	18 mg/l	22 mg/l
7/8/2008	001	Susp. Solids	00530	3.4 kg/day	3.5 kg/day
7/15/2008	001	Ammonia	00610	3.0 mg/l	9.7 mg/l
7/15/2008	001	Ammonia	00610	0.57 kg/day	1.54 kg/day
6/1/2009	001	Ammonia	00610	2.0 mg/l	12.3 mg/l
6/1/2009	001	Ammonia	00610	3.0 mg/l	7.71 mg/l
6/1/2009	001	Ammonia	00610	0.38 kg/day	1.75 kg/day
6/1/2009	001	Ammonia	00610	0.57 kg/day	0.82 kg/day
6/15/2009	001	Ammonia	00610	3.0 mg/l	16.9 mg/l
6/15/2009	001	Ammonia	00610	0.57 kg/day	2.69 kg/day
7/1/2009	001	Ammonia	00610	2.0 mg/l	7.9 mg/l

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

7/1/2009	001	Ammonia	00610	0.38 kg/day	1.44 kg/day
7/22/2009	001	Ammonia	00610	3.0 mg/l	15.2 mg/l
7/22/2009	001	Ammonia	00610	0.57 kg/day	2.82 kg/day

The specific instances of noncompliance and/or deficiencies for 1PP00005 were as follows:

Numerical Violations

Date	Station	Parameter	Code	Permit Requirements	Reported
7/1/2009	001	Ammonia	00610	2.0 mg/l	5.45 mg/l
7/1/2009	001	Ammonia	00610	0.60 kg/day	0.76 kg/day
7/22/2009	001	Ammonia	00610	3.0 mg/l	10.9 mg/l
7/22/2009	001	Ammonia	00610	0.91 kg/day	1.53 kg/day

Within 14 days of the date of this Notice of Violation, please inform this office, in writing, as to the reason for the above referenced numerical violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Please be advised that failure to comply with the effluent limitations or satisfy the monitoring/reporting requirements for your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions regarding the above, please contact me at this office.

Respectfully,

Maureen M. Ware
Division of Surface Water

Ec: Preble County Health Dept.

MMW/mab