



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PB0001920100416

PREBLE

LEWISBURG WWTP

WARE, MAUREEN

2010/04/16

U.S. Postal Service

CERTIFIED MAIL

RECEIPT

(Domestic Mail Only; No In-

ternational Coverage Provided)

For delivery information visit our website at www.usps.com

OFFICIAL USE

7007 0220 0001 2491 6021

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

FROM: MAUREEN
WARE
DIV. OF SURFACE
WTR.

Postmark
Here

8/16/10

Sent To

MAYOR AND COUNCIL LEWISBURG
112 SOUTH COMMERCE STREET BOX 697
LEWISBURG OH 45338

Certified Mail Provides:

- A mailing receipt
- A unique identifier for your mailpiece
- A record of delivery kept by the Postal Service for two years.

Important Reminders:

- Certified Mail may **ONLY** be combined with First-Class Mail[®] or Priority Mail[®].
- Certified Mail is *not* available for any class of international mail.
- **NO INSURANCE COVERAGE IS PROVIDED** with Certified Mail. For valuables, please consider Insured or Registered Mail.
- For an additional fee, a *Return Receipt* may be requested to provide proof of delivery. To obtain Return Receipt service, please complete and attach a Return Receipt (PS Form 3811) to the article and add applicable postage to cover the fee. Endorse mailpiece "Return Receipt Requested". To receive a fee waiver for a duplicate return receipt, a USPS[®] postmark on your Certified Mail receipt is required.
- For an additional fee, delivery may be restricted to the addressee or addressee's authorized agent. Advise the clerk or mark the mailpiece with the endorsement "*Restricted Delivery*".
- If a postmark on the Certified Mail receipt is desired, please present the article at the post office for postmarking. If a postmark on the Certified Mail receipt is not needed, detach and affix label with postage and mail.

IMPORTANT: Save this receipt and present it when making an inquiry.

PS Form 3800, August 2006 (Reverse) PSN 7530-02-000-9047

File: Preble Co
Lewisburg WWTP
sewerage



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

April 16, 2010

Certified Mail

Mayor and Council, Lewisburg
112 South Commerce Street Box 697
Lewisburg, Ohio 45338

RE: Reconnaissance Inspection (RI)/Notice of Violation (NOV)
Lewisburg WWTP
Permit Number 1PB00019

Mayor and Council:

On April 13, 2010, I conducted an RI at the Lewisburg Wastewater Treatment Plant (WWTP). A copy of the inspection report is enclosed. The inspection report contains two unsatisfactory ratings.

Within 14 days of the date of this RI/NOV, please inform this office, in writing, as to the reason for the poor condition of the WWTP, as well as a description of the actions taken or proposed to improve the WWTP condition. Your response should include the dates, either actual or proposed, for completion of the actions. Please be advised that failure to comply with any of the requirements for your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions or comments concerning the contents of this letter, please feel free to contact me at (937) 285-6103.

Sincerely,

Maureen M. Ware
Division of Surface Water

Enclosure

cc: Troy Burke
ec: Preble County Health Department

MMW/bp



State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PB00019	OH0026051	04/13/2010	R	S	1


Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Lewisburg WWTP 400 Tillman Ln. Lewisburg, Ohio	12:45 PM	5/1/2010
	Exit Time	Permit Expiration Date
	1:30 PM	4/30/2015
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Troy Burke, Operator	937-313-0805	
Name, Address and Title of Responsible Official	Phone Number	
Mayor and Council 112 South Commerce Street Box 697 Lewisburg, Ohio		

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
N	Permit	N	Flow Measurement	N	Pretreatment
N	Records/Reports	N	Laboratory	N	Compliance Schedule
U	Operations & Maintenance	U	Effluent/Receiving Waters	N	Self-Monitoring Program
N	Facility Site Review	N	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)

The clarifiers had sludge clumps and scum covering the entire surface. Sludge was seen going over the v-notches in the clarifier weirs. Sludge lined the clarifier troughs. Sludge deposits were present in the creek downstream of station 1PB00019. As a result, both Operations & Maintenance and Effluent/Receiving Waters were rated as unsatisfactory.

Lewisburg did have the 24 hour flow proportionate sampler on-line and operational.

Inspector	Reviewer
 Maureen M. Ware Division of Surface Water Southwest District Office	 Martyn Burt Environmental Supervisor Division of Surface Water Southwest District Office
Date 4/16/10	Date 4/19/10