



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korteski, Director



1H0001220110613

PREBLE P&G PET CARE - LEWISBURG PROD SUPPLY WARE, MAUREEN 2011/06/13



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 13, 2011

Crystal Taulbee, HS&E Program Leader
P&G Pet Care
6571 State Route 503 North
Lewisburg, Ohio 45338

RE: P&G Pet Care WWTP Reconnaissance Inspection (RI)

Dear Ms. Taulbee:

On June 9, 2011 I conducted an RI at the P&G Pet Care WWTP facility. A copy of my inspection report is enclosed. The inspection report contains no marginal ratings or unsatisfactory ratings.

If you have any questions or comments concerning the contents of this letter, please feel free to contact me at (937) 285-6103.

Sincerely,

Maureen M. Ware
Division of Surface Water

Enclosures

cc: Preble County Health Dist.

MW/mab




State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1IH00012	OH0072770	6/9/11	C	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Proctor & Gamble IAMs Co. 6571 SR 503 Lewisburg, Ohio	12:15PM	10/1/2008
	Exit Time	Permit Expiration Date
	1:10PM	09/30/2013
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Crystal Taulbee, HS&E Program Leader P&G Pet Care R&D	937-962-7237	
Name, Address and Title of Responsible Official	Phone Number	
Proctor & Gamble	1-800-675-3849	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measurement	N	Pretreatment
S	Records/Reports	N	Laboratory	N	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	S	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
<p>The IAMs facility has ceased almost all production. All production will cease as of August 2011. At that time, the remaining function of the facility will be care of IAMs animals (approximately 200 animals). About 80 people will be needed for the care of the animals. Wastewater flow will consist of wastewater from employee restrooms, and wash down wastewater from the kennels. Flow volume is estimated to be 15,000 gallons per day at that time. Exact flow numbers will be determined after August 2011. IAMs had some violations since the last inspection, but they have sent proper notification including how the violations were to be addressed.</p>	
Inspector	Reviewer
 Maureen M. Ware Division of Surface Water Southwest District Office	 Martyn G. Burt Environmental Supervisor Division of Surface Water Southwest District Office
Date 6/15/11	Date 6/15/11