Ohio | Environmental Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

1PA0002720100927

PREBLE VERONA WWTP WARE, MAUREEN 2010/09/27

50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 644 3020
614 | 644 3184 (fax)
www.epa.ohio.gov

File: Preble
Verona
Sewerage

Ohio | Environmental Protection Agency

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

September 27, 2010

Verona Mayor and Council
100 West Main Street
Verona, Ohio 45378

RE: Verona WWTP Compliance Enforcement Inspection (CEI)

Ladies and Gentlemen:

On September 21, 2010 I conducted a CEI at the Verona WWTP facility. A copy of my inspection report is enclosed. The inspection report contains no marginal or unsatisfactory ratings. Gary Wagner must submit the new Operator of Record Notification form.

The link for the form is:
http://www.epa.state.oh.us/portals/28/documents/opcert/Operator_of_Record_Notification_Form.pdf

If you have any questions or comments concerning the contents of this letter, please feel free to contact me at (937) 285-6103.

Sincerely,

Maureen M. Ware
Division of Surface Water

Enclosures

ec: Gary Wagner, ORC
Preble County Health District

MMW\bp

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

Permit # : 1PA00027
NPDES #: OH0131849

OhioEPA

State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	**NPDES#**	**Month/Day/Year**	**Inspection Type**	**Inspector**	**Facility Type**
1PA00027	OH0131849	9/21/2010	C	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	**Entry Time**	**Permit Effective Date**
Verona WWTP S. side of W. Main St. Verona, Ohio 45378	9:00 AM	1/1/2006
	Exit Time	**Permit Expiration Date**
	10:20AM	12/31/2010
Name(s) and Title(s) of On-Site Representatives	**Phone Number(s)**	
Gary Wagner, Operator	937-533-0082	
Name, Address and Title of Responsible Official	**Phone Number**	
Verona Mayor and Council		

Section C: Areas Evaluated During Inspection (S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measurement	N	Pretreatment
S	Records/Reports	S	Laboratory	N	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	S	Sludge Storage/Disposal	N	Other
S	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)

At this time, Verona is only using one half of the WWTP due to low influent flow. Verona currently uses sanitary land filling and hauling (to New Madison's WWTP) for sludge disposal. However, they wish to keep land application in the NPDES permit for possible future use. A new ORC form must be submitted for the Verona WWTP.

Inspector	Reviewer
9/27/10	9/27/10
Maureen M. Ware Division of Surface Water Southwest District Office Date	Martyn G. Burt Environmental Supervisor Division of Surface Water Southwest District Office Date

Permit # : 1PA00027
NPDES #: OH0131849

Sections E thru K: Complete on all inspections as appropriate
Y – Yes, N – No, N/A – Not Applicable, N/E – Not Evaluated

Section E: Permit Verification

Inspection observations verify the permit

(a) Correct name and mailing address of permittee	Y
(b) Flows and loadings conform with NPDES permit.....	Y
(c) Treatment processes are as described in permit application...	Y
(d) All discharges are permitted.....	Y
(e) Number and location of discharge points are as described in permit.....	Y
(f) Storm water discharges properly permitted.....	N/A

Comments/Status:

Section F: Compliance

(a) Any significant violations since the last inspection.....	N/A
(b) Appropriate Non-compliance notification of violations.....	Y
(c) Permittee is taking actions to resolve violations.....	Y
(d) Permittee has a compliance schedule.....	N/A
(e) Compliance schedule contained in...N/A	
(f) Permittee is in compliance with schedule.....	N/A
(g) Has biomonitoring shown toxicity in discharge since last inspection	N/A

Comments/Status:

There were 3 violations in the review period of April 1, 2008 through August 30, 2010. They are as follows: February 8, 2009 Ammonia Nitrogen 7 day concentration, permit limit 4.5 mg/l, reported value 5.34 mg/l. February 22, 2010 Ammonia Nitrogen 7 day concentration permit limit 4.5 mg/l, reported value 9.0 mg/l. February 1, 2010 Ammonia Nitrogen 30 day concentration permit limit 3.0 mg/l, reported value 4.621 mg/l.

Permit # : 1PA00027
NPDES #: OH0131849

Section G: Operation & Maintenance

Treatment Works:

Treatment facility properly operated and maintained.....Y

(a) Standby power available.....generator ☒ or dual feed ☐..... Y

i. What does the back-up power source operate.....

Everything

ii. How often is the generator tested under load.....

weekly

(b) Which components have an alarm system available for power or equipment failures.....

All WWTP pumps and the generator.

(c) All treatment units in service other than backup units..... N

(d) What method is used for scheduling routine & preventative maintenance (calendar, software, etc.).....

Calendar

(e) Any major equipment breakdown since last inspection..... N

(f) Operation and maintenance manual provided and maintained..... Y

(g) Any plant bypasses since last inspection..... N

(h) Any plant upsets since last inspection..... N

Comments/Status:

Only one half of the WWTP is on line at this time due to low influent flow.

Section G: Operation & Maintenance con't

Record Keeping/Operator of Record:

(a) Wastewater Treatment Works classification (OAC 3745-7)..... I
(b) Operator of Record holds unexpired license of class required by Permit..... Y
(c) Copy of certificate of Operator of Record displayed on-site..... Y
(d) Has the Operator of Record submitted an ORC Notification form.. N
(e) Minimum operator staffing requirements fulfilled (OAC 3745-7).... Y
(f) If a Staffing Reduction plan has been approved, are the stipulations of the plan being met.....N/A
(g) Operator of Record log book provided..... Y
(h) Format of log book (e.g. computer log, hard bound book)

hardbound book

(i) Log book kept onsite (in an area protected from weather).....Y
(j) Log book contains the following:
  I. Identification of treatment works..... Y
  II. Date/times of arrival/departure for Operator of Record and any other operator required by OAC 3745-7..... Y
  iii. Daily record of operator and maintenance activities (including preventative maintenance, repairs and request for repairs, process control test results, etc.)..... Y
  iv. Laboratory results (unless documented on bench sheets)... Y
  v. Identification of person making entries..... N/A
(k) Has the Operator of Record submitted written notifications to the permittee, Ohio EPA and, if applicable, any local environmental agencies when a collection system overflow, treatment plant bypass or effluent limit violation has occurred..... Y

Comments/Status:

Gary Wagner submitted an ORC form about 4 years ago. I did tell him the form has since changed, and as such, he needs to submit the new form. Gary is the only operator at Verona, therefore the identification of the person making entries in the logbook is N/A.

Section G: Operation & Maintenance con't

Collection System:

(a) Are there pump stations in the collection system..... Y
- i. How many publicly-owned pump stations equipped with permanent standby power or equivalent.....1
- ii. How many pump stations have telemetered alarms.....0
- iii. How many pump stations have operable alarms.....1

(b) Any chronic collection system overflows since last inspection..... N
(c) Regulatory agency notified of all overflows..... N/A
(d) Are there CSOs in the collection system..... N/A
if so, what is the LTCP status.....

(e) How are CSOs monitored (chalk, block, level sensor, etc.).....

(f) Portable pumps available for collection system maintenance..... N
(g) RDII Program established and active..... N
(h) Any WIB complaint received since last inspection..... N
(i) Is there a WIB response plan..... N
(j) Is any portion of the collection system at or near dry weather capacity..... N

Comments/Status:

Verona's WWTP and collection system are only a couple of years old. As such, there is no RDII or WIB programs at this time.

Permit # : 1PA00027
NPDES #: OH0131849

Section H: Sludge Management

Pathogen Reduction Alternative	84370 Vector Attraction Reduction Options									
	Option 1 -38% Volatile Solids Reduction	Option 2 -Anaerobic Bench Scale Analysis	Option 3 – Aerobic Bench Scale Analysis	Option 4 – Specific Oxygen Uptake Rate	Option 5 – Aerobic Time and Temperature	Option 6 – Alkali Addition	Option 7 – >75% Percent Solids without Unstabilized	Option 8 - >75% Percent Solids with Unstabilized	Option 9 – Land Injection	Option 10 – Immediate Incorporation
Alternative 1 - Geometric Mean of Seven Fecal Samples (84369)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 - Aerobic Digestion (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☒	☐
Alternative 2 - Air Drying (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 - Anaerobic Digestion (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 – Composting (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 - Lime Treatment (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 3 – Approved Equivalent Process	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐

(a) Method of Sludge Disposal... ☒Land Application
☒Haul to Another NPDES Permitee
☒Haul to a Mixed Solid Waste Landfill

(b) Has amount of sludge generated changed significantly since the last inspection..... Y

(c) How much sludge storage is provided at the plant.....
6-9 months.

(d) Records kept in accordance with State and Federal law (5 years according to OAC 3745-40-06)..... Y

(e) Any complaints received in last year regarding sludge..... N

(f) 5/8" screen at headworks for facilities that land apply sludge..... N

(g) Are sludge application sites inspected to verify compliance with NPDES permit..... N/A

(h) Is a contractor used for sludge disposal..... Y
If so, what is the name of the contractor.....
Freck (out of New Madison)

Comments/Status:

At this time Verona is not using their land application of sludge option, however they wish to keep it in the permit for possible future use.

Section I: Self-Monitoring Program

Flow Measurement:

(a) Primary/Secondary flow measuring devices (e.g. weir with ultrasonic level sensor):

Ultrasonic and weir

(b) Flow meter calibrated annually ..... Y
(Date of last calibration: 9/2010)

(c) 24-hour recording instruments operated and maintained..... Y

(d) Flow measurement equipment adequate to handle full range of flows..... Y

(e) All discharged flow is measured..... Y

Comments/Status:

Section I: Self-Monitoring Program (con't)

Sampling:

(a) Sampling location(s) are as specified by permit..... Y

(b) Parameters and sampling frequency agree with permit..... Y

(c) Permittee uses required sampling method..... Y
(See GLC)

(d) Monitoring records (i.e., flow, pH, DO) maintained for a minimum of three years including all original strip chart recordings (i.e, continuous monitoring instrumentation, calibration and maintenance records)..... Y

Comments/Status:

Section I: Self-Monitoring Program (con't)

Laboratory:

General

(a) Does the Quality Assurance Manual contain written Standard Operating Procedures (SOP's) for all analysis performed onsite..... Y

(b) Do SOP's include the following if applicable..... Y

- Title
- Scope and Application
- Summary
- Sample Handling and Preservation
- Interferences
- Apparatus and Materials
- Reagents
- Procedure
- Calculations
- Quality Control
- Maintenance
- Corrective Action
- Reference (Parent Method)

Note: Standard Methods 1020A establishes that "Quality assurance (QA) is the definitive program for laboratory operation that specifies the measure required to produce defensible data of know precision and accuracy. Standard operating procedures are to be used in the laboratory in sufficient detail that a competent analyst unfamiliar with the method can conduct a reliable review and/or obtain acceptable results." SOPs should be developed for each analytical procedure.

(c) EPA approved analytical testing procedures used (40 CFR 136.3).. Y

(d) If alternate analytical procedures are used, proper approval has been obtained..... N/A

(e) Analyses being performed more frequently than required by permit. N

(f) If (e) is yes, are results in permittee's self-monitoring report..... N/A

(g) Satisfactory calibration and maintenance of instruments/equipment. Y (see GLC)

(h) Commercial laboratory used..... Y

Parameters analyzed by commercial lab: Everything except D.O., pH, and temperature.

Lab name: Belmont

Discharge Monitoring Report Quality Assurance (DMRQA)

(a) Participation in latest USEPA quality assurance performance sampling..... N/A

Date:

(b) Were any parameters "Unsatisfactory"..... N/A

(c) Reasons for "Unsatisfactory" parameters.....

Permit # : 1PA00027
NPDES #: OH0131849

Comments/Status:

Section J: Effluent/Receiving Water Observations

Outfall # 001
Outfall Description: Pipe

Receiving Stream: Swamp Creek
Receiving Stream Description: Clear

Comments/Status:

Section K: Multimedia Observations

(a) Are there indications of sloppy housekeeping or poor maintenance in work and storage areas or laboratories..... N
(b) Do you notice staining or discoloration of soils, pavement or floors.. N
(c) Do you notice distressed (unhealthy, discolored, dead) vegetation.. Y
(d) Do you see unidentified dark smoke or dust clouds coming from sources other than smokestacks..... N
(e) Do you notice any unusual odors or strong chemical smells..... N
(f) Do you see any open or unmarked drums, unsecured liquids, or damaged containment facilities..... N

If any of the above are observed, ask the following questions:
(1) What is the cause of the condition?
(2) Is the observed condition or source a waste product?
(3) Where is the suspected contaminant normally disposed?
(4) Is this disposal permitted?
(5) How long has the condition existed and when did it begin?

Comments/Status: Since the area is in a near drought, the grass was a bit on the dry and brown side.

C neral Lab Criteria

Criteria	Standard Methods Requirement			Rating
Balance		Acceptable?		
• Standard Weights	• Either NIST Class s or ASTM/ANSI Class 1 weights [1,2]	☐ Yes	☐ No	
• Calibration Frequency / Documentation	• Calibration verification required at least once each day the balance is used.[3]	☐ Yes	☐ No	
• Cleanliness, air movement, vibration	• Cleanliness of balance is a must and air movement and vibration needs to be kept to a minimum[1]	☐ Yes	☐ No	
• Other	• Service and recalibrate annually (manufacturer representative or comparable)[1]	☐ Yes	☐ No	
	• Must be able to measure to 0.1 grams[4]	☐ Yes	☐ No	
	• Instrument manual available	☐ Yes	☐ No	
	• Log book maintained[2]	☐ Yes	☐ No	

Comments: :

Criteria	Standard Methods Requirement			Rating
Drying Oven (Suspended Solids)		Acceptable?		
• Temperature Recordkeeping	• Temperature recorded with each use[4]	☐ Yes	☐ No	
	• Log book maintained[2]	☐ Yes	☐ No	
• Calibration Frequency / Documentation	• Thermometer calibrated annually with NIST traceable thermometer[1,2]. Correction factor posted on thermometer / equipment[1]	☐ Yes	☐ No	
• Other	• Thermometer temperature in 0.5° C increments[5]	☐ Yes	☐ No	
	• Acceptable temperature range is 103° – 105° F [4]	☐ Yes	☐ No	
	• Instrument manual available	☐ Yes	☐ No	

Comments: :

General Lab Criteria

Criteria	Standard Methods Requirement			Rating
pH Meter		Acceptable?		
• Calibration Frequency / Documentation	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples)[3]	☐ Yes	☐ No	
	• Logbook maintained[2]	☐ Yes	☐ No	
• Minimum of 2 point calibration	• Calibration per manufacturer specification and calibration buffers must bracket anticipated result[7]	☐ Yes	☐ No	
• Slope Documentation / Acceptability	• Slope acceptable range indicated on benchsheet[2]	☐ Yes	☐ No	
• Buffer Expiration Date	• Buffers must not be expired	☐ Yes	☐ No	
• Other	• Instrument manual available	☐ Yes	☐ No	
	• Teflon covered magnetic stirrer or equivalent for mixing[8]	☐ Yes	☐ No	

Comments: :

Criteria	Standard Methods Requirement			Rating
Dissolved Oxygen Meter		Acceptable?		
• Calibration Method	• Air or known DO calibration method[10]	☒ Yes	☐ No	
	• Calibration per manufacturer specification[10]	☒ Yes	☐ No	
• Calibration Frequency / Documentation	• Logbook maintained[2]	☒ Yes	☐ No	
	• Calibration verification required at least once each day the meter is used.[3]	☒ Yes	☐ No	
• Other	• Small to no bubble present under membrane (must be smaller than the lead in number 2 pencil)[11]	☒ Yes	☐ No	
	• Instrument manual available	☒ Yes	☐ No	

Comments:

C neral Lab Criteria

Criteria	Standard Methods Requirement			Rating
Incubator (CBOD/ E-Coli)		Acceptable?		
• Temperature Recordkeeping	• Temperature checked / recorded twice daily for each shelf in use[1] (E-Coli)	☐ Yes	☐ No	
	• Temperature checked / recorded daily[2] (CBOD)	☐ Yes	☐ No	
	• Acceptable temperature range (CBOD) is 20° C ±1.0°[12]	☐ Yes	☐ No	
	• Acceptable temperature range (E-Coli) is 35° C ±0.5°[22]	☐ Yes	☐ No	
	• Logbook maintained[2]	☐ Yes	☐ No	
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer[1, 2]	☐ Yes	☐ No	
	• Temperature correction information posted on incubator[1]	☐ Yes	☐ No	
• E-Coli can use multiple tubes (five 20 ml or ten 10 ml), or mfg's multi-well tray	• E-coli Ultraviolet lamp (365 nm wave length, 6 W bulb)[23]	☐ Yes	☐ No	
• Other	• Instrument manual available	☐ Yes	☐ No	
	• Temperature Log (thermometer reads to 0.5 Celsius).[1]	☐ Yes	☐ No	

Comments: :

Criteria	Standard Methods Requirement			Rating
Refrigerator		Acceptable?		
• Temperature Recordkeeping	• Temperature Log (thermometer reads to 0.5 Celsius).[5]	☐ Yes	☐ No	
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer[1, 2]	☐ Yes	☐ No	
• Other	• Thermometer held in water bath.[1]	☐ Yes	☐ No	
	• Refrigerator temperature ≤6° Celsius.[13]	☐ Yes	☐ No	
	• Do not store volatile solvents, food, or beverages.[14]	☐ Yes	☐ No	

Comments:

General Lab Criteria

Criteria	Standard Methods Requirement			Rating
Chlorine Meter		Acceptable?		
• Calibration Frequency / Documentation	• pH / millivolt meter read to 0.1 mV[15]	☐ Yes	☐ No	
	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples)[3]	☐ Yes	☐ No	
• Calibration Method	• Calibration using three iodate solutions 0.2, 1.0, 5.0 milliliters or calibration per manufacturer specification[16]	☐ Yes	☐ No	
	• Standards used for calibration not expired	☐ Yes	☐ No	
• Slope Documentation / Acceptability	• Calibration curve (acceptable slope)	☐ Yes	☐ No	
• Other	• Electrode free of deposits and foreign material	☐ Yes	☐ No	
	• Log book being maintained.[2]	☐ Yes	☐ No	
	• Instrument manual available	☐ Yes	☐ No	

Comments: :

Criteria	Standard Methods Requirement			Rating
Ammonia Meter		Acceptable?		
• Calibration Frequency / Documentation	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples)[3]	☐ Yes	☐ No	
	• Log book being maintained[2]	☐ Yes	☐ No	
• Slope acceptability	• Verify calibration slope is acceptable (per mfg. spec.).	☐ Yes	☐ No	
• Calibration Method	• Standards used for calibration (3 ammonia solutions of 10 mg/l, 1 mg/l, and 0.1 mg/l) or per mfg. spec.[17]	☐ Yes	☐ No	
	• Standards used for calibration not expired	☐ Yes	☐ No	
• Other	• Electrode free of deposits and foreign material	☐ Yes	☐ No	
	• Teflon covered magnetic stirrer or equivalent for mixing[18]	☐ Yes	☐ No	
	• Instrument manual available	☐ Yes	☐ No	

Comments: :

C neral Lab Criteria

Criteria	Standard Methods Requirement			Rating
Sample Collection/Handling		Acceptable?		
• Sample Labeling	• Samples container labeled (description, date, time, preservative added, initialed).[19]	☒ Yes	☐ No	
• Chain of Custody	• Chain of custody (description, date, time, signature).[19]	☒ Yes	☐ No	
• Other	• Composite samples refrigerated during sample collection[14]	☒ Yes	☐ No	
	• Equipment blanks utilized[14]	☐ Yes	☐ No	
	• SOP for cleaning of sampling equipment	☐ Yes	☐ No	
	• Logbook being maintained[2]	☐ Yes	☐ No	

Comments: Sample labels going to Belmont have everything except the intials as there is no area for initials on the lable at this time. Verona does not have an autosampler as they are under 100,000 ADDF.

Criteria	Standard Methods Requirement			Rating
Desiccator		Acceptable?		
• General criteria	• Properly working seals.	☐ Yes	☐ No	
	• Desiccant fresh (blue color)	☐ Yes	☐ No	
• Documentation	• Log book being maintained[2]	☐ Yes	☐ No	

Comments:

Criteria	Standard Methods Requirement			Rating
Bench sheets		Acceptable?		
• General criteria	• Date(s)[2]	☒ Yes	☐ No	
	• Analyst initials[2]	☒ Yes	☐ No	
	• Blue or black ink pen[2]	☒ Yes	☐ No	
	• Calibration information[2]	☒ Yes	☐ No	
	• Equations, calculations, units for all measurements, notations, and results present[2]	☒ Yes	☐ No	
	• Corrections, single line through, initialed and dated[2]	☐ Yes	☐ No	

Comments: For D.O. there are no required calculations or equations to be put on the bench sheet. No corrections were noted on the bench sheets viewed.

General Lab Criteria

C neral Lab Criteria

Criteria	Standard Methods Requirement			Rating
Hot Water Bath (Fecal Coliform/E. Coli)		Acceptable?		
• Temperature Recordkeeping	• Temperature Log (thermometer reads 0.2° C)[21]	☐ Yes	☐ No	
	• Incubator temperature 44.5° C ± 0.2° [21/24]			
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer [1, 2]	☐ Yes	☐ No	
	• Log book being maintained [2]	☐ Yes	☐ No	
• Water Level	• Thermometer total immersion or partial (line on thermometer to ID immersion depth) [1, 5]	☐ Yes	☐ No	
Comments:				

Criteria	Standard Methods Requirement			Rating
Autoclaves/Steam Sterilizers		Acceptable?		
• All apparatus utilized is adequately sterilized before use	• Sterilizing temperature 121° C [25]	☐ Yes	☐ No	
	• 10 to 30 minutes time based on material being sterilized[26]	☐ Yes	☐ No	
• Documentation	• Verify the autoclave temperature weekly by using a maximum registering thermometer (MRT) to confirm that 121°C has been reached as measured in the exhaust. [1]	☐ Yes	☐ No	
	• Date, contents, sterilization time and temperature, total time in autoclave, and analyst's initials should be recorded each time the autoclave is used [1]	☐ Yes	☐ No	
• Temperature Calibration / Documentation	• Thermometer calibrated annually with NIST traceable thermometer [1,2]	☐ Yes	☐ No	
	• Log book being maintained [2]	☐ Yes	☐ No	
• Performance Checks	• Test monthly for efficacy using a biological such as commercially available *Geobacillus stearothermophilus* in spore strips, suspensions, or capsules [1]	☐ Yes	☐ No	
Comments:				

General Lab Criteria

Criteria	Standard Methods Requirement			Rating
Final Effluent Temperature Monitoring		Acceptable?		
• General Criteria	• Thermometer calibrated annually with NIST traceable thermometer [1,2]	☐ Yes	☐ No	
	• Thermometer reads in increments of at least 0.1° C [5]	☐ Yes	☐ No	
	• Log book being maintained [2]	☐ Yes	☐ No	
Comments:				

Number of Criteria Rated:	**Acceptable**	
	Marginal	
	Unacceptable	
	Total Number of Areas Rated	

Acceptable Ratings – No action required (recommend SOP's written or updated, perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, written response not required).

Marginal Ratings – Improvements required, written response required (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response).

Unsatisfactory Rating - Improvements required, written response required, NOV issued (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response to NOV).

Consider recommending PAI Audit from DES when:	>60% of ratings are Marginal >45% of ratings are a combination of Marginal or Unacceptable >30% of ratings are Unacceptable

Notation of Referenced Method

1 Method 9020-B, Item 3
2 Method 1020-A, Item 1
3 Method 1020-B, Item 10
4 Method 2540-B, Item 2
5 Method 2550-B, Item 1
6 Method 1020-A, Item 1
7 Method 4500-H B, Item 4
8 Method 4500-H B, Item 2
9 Method 1020-B, Item 2
10 Method 4500-O B, Item 3
11 Method 4500-O G, Item 3
12 Method 5210-B, Item 5
13 CFR 136.3, Table II
14 Method 1060A, Item 1
15 Method 4500-Cl I, Item 2
16 Method 4500-Cl I, Item 4
17 Method 4500-NH3 D, Item 4
18 Method 4500-NH3 D, Item 2
19 Method 1060-B, Item 2
20 Method 1060-B, Item 1
21 Method 9222D, Item 1
22 Method 9223 B, Item 2
23 Method 9223 B, Item 3
24 Method 1603, Item 2
25 Method 9030-B, Item 3
26 Method 9020 B, Table IV

General Lab Criteria

Equipment Logbook Content - all maintenance performed on a piece of equipment should be documented in the logbook. This should include parts replacement and routine maintenance activities. Entries should include date, maintenance performed and initials of person making entry.

Preservation and Holding Times

Parameter	Container	Min. Sample Size (mL)	Sample Type	Preservation	Maximum Storage Time	
					Recommended	Regulatory
BOD / CBOD	P, G	1000	G, C	Refrigerate ≤6° C	6h	48h
TSS	P, G	200	G, C	Refrigerate ≤6° C	7 d	7 d
pH	P, G	50	G	Analyze immediately	0.25h	0.25 h
NH3-N	P, G	500	G, C	Analyze as soon as possible or add H_2SO_4 to pH <2, Refrigerate ≤6° C	7 d	28 d
TRC	P, G	500	G	Analyze immediately	0.25h	0.25 h
DO (electrode)	G, BOD Bottle	300	G	Analyze immediately	0.25h	0.25 h
Temperature	P, G	--	G	Analyze immediately	0.25h	0.25 h
Metals, general	P, G	1000	G, C	For dissolved filter immediately and add HNO_3 to pH <2	6 months	6 months
Purgeables by purge and trap	G (PTFE lined lid)	40 (X2)	G	HCl to pH<2, Refrigerate ≤6° C	7 d	14 d
Base/Neutrals and acids	G (solvent rinsed or baked)	1000	C, G	Refrigerate ≤6° C	7 d	7 days until extraction 40 days after extraction
Pesticides	G (PTFE lined lid)	1000	C	Refrigerate ≤6° C	7 d	7 days until extraction 40 days after extraction
Fecal Coliform / E-Coli	G, P (Sterilized)	100	G	Refrigerate ≤10° C If chlorine present, add sodium thiosulfate tablet	6 hrs transport Start analysis within 2 hrs of receipt in lab.	
Oil and Grease	G	1000	G	HCl or H_2SO_4 to pH <2, Refrigerate ≤6° C	28 d	28 d

Approved Standard Methods

CBOD / BOD 5 Day	Std Methods 5210-B
Ammonia, Selective Electrode Method	Std Methods 4500-NH3 D
Total Residual Chlorine, DPD Colorimetric Method	Std Methods 4500-Cl G
Total Suspended Solids, Dried at 103-105 °C	Std Methods 2540-D
Dissolved Oxygen, Membrane Electrode Method	Std Method 4500-O G
pH, Electrometric Method	Std Methods 4500-H+ B
Fecal Coliform, Membrane Filter Procedure	Std Methods 9222D
Escherichia Coli, Enzyme Substrate Test	Std Method 9223B
Escherichia Coli Membrane Filtration Procedure	EPA Method 1603
Oil and Grease	USEPA 1664A or Std Methods 5520B
Metals, general	USEPA 200, Std Methods 3111B or C, or 3120B
Volatiles (Purgeables by purge and trap)	USEPA 6210, Std Methods 624
Semi-Volatiles (Base/Neutrals and acids)	USEPA 6410, Std Methods 625
Pesticides	USEPA 6410 and 6630, Std Methods 608