



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director



\*1PB0003520080131\*

PREBLE

WEST ALEXANDRIA WWTP

WARE, MAUREEN

2008/01/31

File: Preble  
W. Alexandria  
Sewerage



State of Ohio Environmental Protection Agency

**Southwest District Office**

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 286-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 31, 2008

**CERTIFIED MAIL**

Mr. Christopher M. Day, Superintendent  
Utilities  
P.O. Box 265  
West Alexandria, Ohio 45381

RE: Village of West Alexandria WWTP Notice of Violation (NOV)

Dear Mr. Day:

We have received your self-monitoring report covering the months of January 2007 through December 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies were as follows:

Numerical Violations

<u>Date</u>	<u>Station</u>	<u>Parameter</u>	<u>Code</u>	<u>Permit Requirements</u>	<u>Reported</u>
3/15/07	001	TSS	00530	20.4 kg/D 7D Qty.	24.4132 kg/D
6/11/07	001	pH	00400	6.5 S.U min.	6.4 S.U.
6/25/07	001	pH	00400	6.5 S.U min.	6.4 S.U.
7/9/07	001	pH	00400	6.5 S.U min.	6.2 S.U.
8/1/07	001	TSS	00530	20.4 kg/D 7D Qty.	26.0483 kg/D
8/1/07	001	TSS	00530	12 mg/l 30D Conc.	23.875 mg/l
8/1/07	001	TSS	00530	18 mg/l 7D Conc.	62 mg/l
8/15/07	001	Fecal Coli	31616	2000/100 ml 7D Conc.	2086.83/100 ml
9/22/07	001	TSS	00530	18 mg/l 7D Conc.	20.5 mg/l
10/1/07	001	TSS	00530	12 mg/l 30D Conc.	13.75 mg/l
10/1/07	001	TSS	00530	18 mg/l 7D Conc.	26.5 mg/l
10/15/07	001	Fecal Coli	31616	2000/100 ml 7D Conc.	4184.13/100 ml
10/22/07	001	pH	00400	6.5 S.U min.	6.0 S.U.
10/23/07	001	pH	00400	6.5 S.U min.	6.3 S.U.
10/24/07	001	pH	00400	6.5 S.U min.	6.0 S.U.
11/8/07	001	TSS	00530	18 mg/l 7D Conc.	19 mg/l

Page 2  
January 31, 2008  
West Alexandria

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations (and violations noted in the 9/29/06 letter), as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions regarding the above, please contact me at this office.

Respectfully,



Maureen M. Ware  
Division of Surface Water

cc: Mayor and Council  
Village of West Alexandria

cc: Preble County Health Dept.