



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korteski, Director



\*1PZ0000720071212\*

SHELBY

SUPER STOP PETROLEUM ANNA OH

MILLER, JOSEPH

2007/12/12



State of Ohio Environmental Protection Agency

**Southwest District Office**

401 E. Fifth St.  
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 12, 2007

Super Stop Petroleum, Inc.  
Sav-A-Ton Truck Stop, Anna OH  
6221 West Atlantic Boulevard  
Margate, FL 33063

**CERTIFIED MAIL**

**RE: Reconnaissance Inspection/NOTICE OF VIOLATION  
Sav-A-Ton Wastewater Treatment Plant  
NPDES Permit 1PT00039\*FD/OH0046744  
Anna, Shelby County, Ohio**

Ladies and Gentlemen:

On November 1, 2007, I conducted an inspection at the above referenced wastewater treatment works. This inspection was conducted to determine compliance with the NPDES permit for this facility. At the time of inspection, I was unable to determine if the wastewater plant was operating. The area surrounding the wastewater plant was overgrown with vegetation. Numerous effluent violations were noted during the period evaluated.

The NPDES permit for this facility includes a Schedule of Compliance to provide a complete and approvable permit to install (PTI) for wastewater improvements by **September 1, 2005**, commence construction of wastewater improvements by **February 1, 2006**, complete construction of wastewater improvements by **August 1, 2006**, and attain full compliance with final effluent violations by **December 1, 2006**. Ohio EPA has not received a permit to install for wastewater improvements for this facility. This facility is currently in violation of the conditions of the NPDES permit.

A complete and approvable PTI must be submitted to this office. As outlined in previous correspondence, this facility should evaluate connection to the Village of Anna's sanitary sewer system. The Village is willing to consider a cost share scenario for extension of sanitary sewers.

Provide a response to the following "ITEMS REQUIRING A RESPONSE" by **January 4, 2008**. Your response should include dates, either actual or proposed, for completion of actions.



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

Super Stop Petroleum, Inc. NOV  
December 12, 2007  
Page 2

#### ITEMS REQUIRING A RESPONSE

- 1) **Wastewater Improvements/Schedule of Compliance** – The requirements of the NPDES Permit Schedule of Compliance have not been met. Failure to meet the schedule of compliance is grounds for enforcement action. Provide an approvable permit to install for wastewater improvements as well as a proposed construction schedule.
- 2) **Effluent Violations** - A review of the self-monitoring reports covering the months from April 2005 to October 2007 indicates numerous violations of your NPDES permit. The specific instances of noncompliance are attached. Violations of the NPDES permit must be reported as required as detailed in Part III. Item 12 entitled "Non-compliance Notification". All future violations need to be reported as detailed in the NPDES permit. Inform this office, in writing, as to the reasons for the attached violations, as well as a description of the actions taken or proposed to be taken to prevent any future violations.

If you have any questions, I can be reached at (937) 285-6109.

Sincerely,



Joe Miller

Division of Surface Water

CC: Sunny Chaudhry, Sav-A-Ton Manager  
Shelby County Health Department  
Village of Anna Utility Department  
Donald Freisthler, Operator  
Chris Woodell, Hanson Pipe and Precast



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



State of Ohio Environmental Protection Agency  
Southwest District Office

NPDES Compliance Inspection Report


Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PZ00007*AD	OH0092860	11/01/2007	R	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Super Stop Petroleum, Inc., Sav-A-Ton Truck Stop WWTP 14262 State Route 119 Anna, OH 45302	12:25 PM	November 1, 2004
	Exit Time	Permit Expiration Date
	12:35 PM	October 31, 2009
Name(s) and Title(s) of On-Site Representatives		Phone Number(s)
Sunny Chaudhry, Manager		937-394-2720
Name, Address and Title of Responsible Official		Phone Number
Super Stop Petroleum, Inc. Anna OH 6221 West Atlantic Boulevard Margate, FL 33063		954-977-9728

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	N	Flow Measurement	N	Pretreatment
U	Records/Reports	N	Laboratory	U	Compliance Schedule
N	Operations & Maintenance	M	Effluent/Receiving Waters	M	Self-Monitoring Program
M	Facility Site Review	N	Sludge Storage/Disposal	N	Other
N	Collection System				

**Section D: Summary of Findings (Attach additional sheets if necessary)**

Records/Reports was rated as Unsatisfactory due to failure to submit a Permit to Install.  
 Facility Site Review was rated as Marginal, the area of the wastewater plant was overgrown with vegetation.  
 Effluent was rated as Marginal due to effluent violations.  
 Compliance Schedule was rated as Unsatisfactory. None of the compliance schedule items have been completed as required.  
 Self Monitoring was rated as Marginal due to failure to report effluent violations as required by the NPDES permit.

Inspector	Reviewer
 Date: 12/12/07	 Date: 12/12/07
Joe Miller Division of Surface Water Southwest District Office	Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

**Super Stop Petroleum, Inc. – Sav-A-Ton Truck Stop, Anna OH**

**NPDES Permit 1PZ00007\*AD/OH0092860**

**Effluent Limit Violations from the period from April 2005 to October 2007**

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
April 2005	CBOD 5 day	30D Conc	25.0	38.35	4/1/2005
April 2005	Dissolved Oxygen	1D Conc	5.0	2.	4/11/2005
May 2005	Fecal Coliform	30D Conc	1000	20000.	5/1/2005
May 2005	Fecal Coliform	7D Conc	2000	20000.	5/1/2005
July 2005	Dissolved Oxygen	1D Conc	5.0	1.	7/18/2005
August 2005	Fecal Coliform	30D Conc	1000	1434.	8/1/2005
September 2005	Fecal Coliform	30D Conc	1000	7800.	9/1/2005
September 2005	Fecal Coliform	7D Conc	2000	7800.	9/8/2005
October 2005	Fecal Coliform	30D Conc	1000	20000.	10/1/2005
October 2005	Fecal Coliform	7D Conc	2000	20000.	10/1/2005
October 2005	Dissolved Oxygen	1D Conc	5.0	1.	10/5/2005
November 2005	Dissolved Oxygen	1D Conc	5.0	4.	11/16/2005
December 2005	Total Suspended Solids	30D Conc	30.0	37.	12/1/2005
December 2005	Dissolved Oxygen	1D Conc	5.0	4.	12/7/2005
January 2006	Dissolved Oxygen	1D Conc	5.0	2.	1/19/2006
February 2006	Total Suspended Solids	30D Conc	30.0	42.2	2/1/2006
February 2006	Dissolved Oxygen	1D Conc	5.0	2.1	2/2/2006
March 2006	Total Suspended Solids	30D Conc	30.0	51.	3/1/2006
March 2006	Total Suspended Solids	7D Conc	45.0	51.	3/1/2006
March 2006	CBOD 5 day	30D Conc	25.0	25.02	3/1/2006
March 2006	Dissolved Oxygen	1D Conc	5.0	3.	3/7/2006
May 2006	Fecal Coliform	30D Conc	1000	7490.	5/1/2006
May 2006	Fecal Coliform	7D Conc	2000	7490.	5/8/2006
May 2006	Dissolved Oxygen	1D Conc	5.0	3.	5/9/2006
June 2006	Dissolved Oxygen	1D Conc	5.0	1.	6/15/2006
July 2006	Fecal Coliform	30D Conc	1000	2419.	7/1/2006
July 2006	Fecal Coliform	7D Conc	2000	2419.	7/1/2006
July 2006	Dissolved Oxygen	1D Conc	5.0	1.5	7/5/2006
August 2006	Fecal Coliform	30D Conc	1000	2420.	8/1/2006
August 2006	Fecal Coliform	7D Conc	2000	2420.	8/8/2006
August 2006	Dissolved Oxygen	1D Conc	5.0	2.	8/8/2006
September 2006	Fecal Coliform	30D Conc	1000	2419.	9/1/2006
September 2006	Fecal Coliform	7D Conc	2000	2419.	9/8/2006
October 2006	Fecal Coliform	30D Conc	1000	2419.	10/1/2006
October 2006	Fecal Coliform	7D Conc	2000	2419.	10/8/2006
October 2006	Dissolved Oxygen	1D Conc	5.0	2.	10/11/2006
November 2006	Dissolved Oxygen	1D Conc	6.0	1.5	11/13/2006
December 2006	Total Suspended Solids	30D Conc	12	61.3	12/1/2006
December 2006	Nitrogen, Ammonia (NH3)	30D Conc	3.0	20.98	12/1/2006



December 2006	CBOD 5 day	30D Conc	10	157.	12/1/2006
December 2006	Total Suspended Solids	7D Conc	18	61.3	12/8/2006
December 2006	Nitrogen, Ammonia (NH3)	7D Conc	4.5	20.98	12/8/2006
December 2006	CBOD 5 day	7D Conc	15	157.	12/8/2006
December 2006	Dissolved Oxygen	1D Conc	6.0	3.	12/8/2006
January 2007	Total Suspended Solids	30D Conc	12	45.	1/1/2007
January 2007	CBOD 5 day	30D Conc	10	21.84	1/1/2007
January 2007	Total Suspended Solids	7D Conc	18	45.	1/8/2007
January 2007	CBOD 5 day	7D Conc	15	21.84	1/8/2007
January 2007	Dissolved Oxygen	1D Conc	6.0	1.5	1/9/2007
February 2007	Total Suspended Solids	30D Conc	12	92.	2/1/2007
February 2007	Total Suspended Solids	7D Conc	18	92.	2/1/2007
February 2007	Nitrogen, Ammonia (NH3)	30D Conc	3.0	12.76	2/1/2007
February 2007	Nitrogen, Ammonia (NH3)	7D Conc	4.5	12.76	2/1/2007
February 2007	CBOD 5 day	30D Conc	10	83.7	2/1/2007
February 2007	CBOD 5 day	7D Conc	15	83.7	2/1/2007
February 2007	Dissolved Oxygen	1D Conc	6.0	5.	2/5/2007
March 2007	Total Suspended Solids	30D Conc	12	27.	3/1/2007
March 2007	Total Suspended Solids	7D Conc	18	27.	3/1/2007
March 2007	CBOD 5 day	30D Conc	10	32.82	3/1/2007
March 2007	CBOD 5 day	7D Conc	15	32.82	3/1/2007
March 2007	Dissolved Oxygen	1D Conc	6.0	2.	3/7/2007
April 2007	Dissolved Oxygen	1D Conc	6.0	3.	4/12/2007
May 2007	Fecal Coliform	30D Conc	1000	1986.	5/1/2007
May 2007	Dissolved Oxygen	1D Conc	6.0	5.	5/9/2007
June 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	2.72	6/1/2007
June 2007	Fecal Coliform	30D Conc	1000	2419.	6/1/2007
June 2007	CBOD 5 day	30D Conc	10	16.83	6/1/2007
June 2007	Nitrogen, Ammonia (NH3)	7D Conc	1.5	2.72	6/8/2007
June 2007	Fecal Coliform	7D Conc	2000	2419.	6/8/2007
June 2007	CBOD 5 day	7D Conc	15	16.83	6/8/2007
June 2007	Dissolved Oxygen	1D Conc	6.0	4.	6/12/2007
July 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	4.23	7/1/2007
July 2007	Fecal Coliform	30D Conc	1000	2419.	7/1/2007
July 2007	CBOD 5 day	30D Conc	10	19.53	7/1/2007
July 2007	Nitrogen, Ammonia (NH3)	7D Conc	1.5	4.23	7/15/2007
July 2007	Fecal Coliform	7D Conc	2000	2419.	7/15/2007
July 2007	CBOD 5 day	7D Conc	15	19.53	7/15/2007
July 2007	Dissolved Oxygen	1D Conc	6.0	3.	7/17/2007
August 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	5.36	8/1/2007
August 2007	Fecal Coliform	30D Conc	1000	2419.	8/1/2007
August 2007	CBOD 5 day	30D Conc	10	21.09	8/1/2007
August 2007	Nitrogen, Ammonia (NH3)	7D Conc	1.5	5.36	8/8/2007
August 2007	Fecal Coliform	7D Conc	2000	2419.	8/8/2007
August 2007	CBOD 5 day	7D Conc	15	21.09	8/8/2007
August 2007	Dissolved Oxygen	1D Conc	6.0	5.	8/8/2007
September 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	4.14	9/1/2007
September 2007	Nitrogen, Ammonia (NH3)	7D Conc	1.5	4.14	9/1/2007
September 2007	Fecal Coliform	30D Conc	1000	2419.	9/1/2007
September 2007	Fecal Coliform	7D Conc	2000	2419.	9/1/2007



September 2007	Dissolved Oxygen	1D Conc	6.0	5.	9/6/2007
October 2007	Nitrogen, Ammonia (NH3)	30D Conc	1.0	5.26	10/1/2007
October 2007	Fecal Coliform	30D Conc	1000	2419.6	10/1/2007
October 2007	Nitrogen, Ammonia (NH3)	7D Conc	1.5	5.26	10/15/2007
October 2007	Fecal Coliform	7D Conc	2000	2419.6	10/15/2007
October 2007	Dissolved Oxygen	1D Conc	6.0	5.	10/16/2007

**Super Stop Petroleum, Inc. – Sav-A-Ton Truck Stop, Anna OH**  
**NPDES Permit 1PZ00007\*AD/OH0092860**  
**Effluent Frequency Violations, April 2005 to October 2007**

Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
September 2005	9/8/2005	001	Water Temperature	1/Week	1	0
October 2005	10/8/2005	001	Water Temperature	1/Week	1	0
October 2005	10/8/2005	001	Color, Severity	1/Week	1	0
October 2005	10/8/2005	001	Odor, Severity	1/Week	1	0
October 2005	10/8/2005	001	Turbidity, Severity	1/Week	1	0
October 2005	10/15/2005	001	Water Temperature	1/Week	1	0
October 2005	10/15/2005	001	Color, Severity	1/Week	1	0
October 2005	10/15/2005	001	Odor, Severity	1/Week	1	0
October 2005	10/15/2005	001	Turbidity, Severity	1/Week	1	0
October 2005	10/22/2005	001	Water Temperature	1/Week	1	0
October 2005	10/22/2005	001	Color, Severity	1/Week	1	0
October 2005	10/22/2005	001	Odor, Severity	1/Week	1	0
October 2005	10/22/2005	001	Turbidity, Severity	1/Week	1	0
November 2005	11/1/2005	001	Water Temperature	1/Week	1	0
November 2005	11/1/2005	001	Color, Severity	1/Week	1	0
November 2005	11/1/2005	001	Odor, Severity	1/Week	1	0
November 2005	11/1/2005	001	Turbidity, Severity	1/Week	1	0
November 2005	11/8/2005	001	Water Temperature	1/Week	1	0
November 2005	11/8/2005	001	Color, Severity	1/Week	1	0
November 2005	11/8/2005	001	Odor, Severity	1/Week	1	0
November 2005	11/8/2005	001	Turbidity, Severity	1/Week	1	0
November 2005	11/22/2005	001	Water Temperature	1/Week	1	0
November 2005	11/22/2005	001	Color, Severity	1/Week	1	0
November 2005	11/22/2005	001	Odor, Severity	1/Week	1	0
November 2005	11/22/2005	001	Turbidity, Severity	1/Week	1	0
December 2005	12/8/2005	001	Water Temperature	1/Week	1	0
December 2005	12/15/2005	001	Water Temperature	1/Week	1	0
December 2005	12/22/2005	001	Water Temperature	1/Week	1	0
January 2006	1/1/2006	001	Water Temperature	1/Week	1	0
January 2006	1/1/2006	001	Odor, Severity	1/Week	1	0
January 2006	1/1/2006	001	Turbidity, Severity	1/Week	1	0
January 2006	1/8/2006	001	Water Temperature	1/Week	1	0
January 2006	1/8/2006	001	Odor, Severity	1/Week	1	0
January 2006	1/8/2006	001	Turbidity, Severity	1/Week	1	0
January 2006	1/22/2006	001	Water Temperature	1/Week	1	0



January 2006	1/22/2006	001	Odor, Severity	1/Week	1	0
January 2006	1/22/2006	001	Turbidity, Severity	1/Week	1	0
February 2006	2/1/2006	001	pH	1/Month	1	0
February 2006	2/8/2006	001	Water Temperature	1/Week	1	0
February 2006	2/15/2006	001	Water Temperature	1/Week	1	0
February 2006	2/22/2006	001	Water Temperature	1/Week	1	0
May 2006	5/1/2006	001	Water Temperature	1/Week	1	0
May 2006	5/15/2006	001	Water Temperature	1/Week	1	0
May 2006	5/22/2006	001	Water Temperature	1/Week	1	0
June 2006	6/8/2006	001	Odor, Severity	1/Week	1	0
June 2006	6/8/2006	001	Turbidity, Severity	1/Week	1	0
June 2006	6/22/2006	001	Odor, Severity	1/Week	1	0
June 2006	6/22/2006	001	Turbidity, Severity	1/Week	1	0
August 2006	8/1/2006	001	Turbidity, Severity	1/Week	1	0
August 2006	8/15/2006	001	Turbidity, Severity	1/Week	1	0
August 2006	8/22/2006	001	Turbidity, Severity	1/Week	1	0
September 2006	9/1/2006	001	Water Temperature	1/Week	1	0
September 2006	9/15/2006	001	Water Temperature	1/Week	1	0
September 2006	9/22/2006	001	Water Temperature	1/Week	1	0
January 2007	1/1/2007	001	Water Temperature	1/Week	1	0
January 2007	1/15/2007	001	Water Temperature	1/Week	1	0
January 2007	1/22/2007	001	Water Temperature	1/Week	1	0
January 2007	1/22/2007	001	Color, Severity	1/Week	1	0
January 2007	1/22/2007	001	Odor, Severity	1/Week	1	0
January 2007	1/22/2007	001	Turbidity, Severity	1/Week	1	0
March 2007	3/8/2007	001	Water Temperature	1/Week	1	0
March 2007	3/15/2007	001	Water Temperature	1/Week	1	0
March 2007	3/22/2007	001	Water Temperature	1/Week	1	0
May 2007	5/8/2007	001	Water Temperature	1/Week	1	0
June 2007	6/1/2007	001	Water Temperature	1/Week	1	0
June 2007	6/15/2007	001	Water Temperature	1/Week	1	0
June 2007	6/22/2007	001	Water Temperature	1/Week	1	0
July 2007	7/1/2007	001	Color, Severity	1/Week	1	0
July 2007	7/8/2007	001	Color, Severity	1/Week	1	0
July 2007	7/22/2007	001	Color, Severity	1/Week	1	0



11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100



## Certified Mail Provides:

- A mailing receipt
- A unique identifier for your mailpiece
- A record of delivery kept by the Postal Service for two years

### *Important Reminders:*

- Certified Mail may **ONLY** be combined with First-Class Mail<sup>®</sup> or Priority Mail<sup>®</sup>.
- Certified Mail is *not* available for any class of international mail.
- **NO INSURANCE COVERAGE IS PROVIDED** with Certified Mail. For valuables, please consider Insured or Registered Mail.
- For an additional fee, a *Return Receipt* may be requested to provide proof of delivery. To obtain Return Receipt service, please complete and attach a Return Receipt (PS Form 3811) to the article and add applicable postage to cover the fee. Endorse mailpiece "Return Receipt Requested". To receive a fee waiver for a duplicate return receipt, a USPS<sup>®</sup> postmark on your Certified Mail receipt is required.
- For an additional fee, delivery may be restricted to the addressee or addressee's authorized agent. Advise the clerk or mark the mailpiece with the endorsement "Restricted Delivery".
- If a postmark on the Certified Mail receipt is desired, please present the article at the post office for postmarking. If a postmark on the Certified Mail receipt is not needed, detach and affix label with postage and mail.

**IMPORTANT: Save this receipt and present it when making an inquiry.**

PS Form 3800, August 2006 (Reverse) PSN 7530-02-000-9047

6922 7642 7000 0220 2002

## SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:



SUPER STOP PETROLEUM INC  
 SAV A TON TRUCK STOP ANNA OH  
 6221 WEST ATLANTIC BOULEVARD  
 MARGATE FL 33063

2. Article Number

*(Transfer from service label)*

## COMPLETE THIS SECTION ON DELIVERY

A. Signature

X

 Agent Addressee

B. Received by (Printed Name)

J. Stern

C. Date of Delivery

12/17

D. Is delivery address different from item 1?  Yesor delivery address below:  No
 Registered Mail
 Express Mail Insured Mail Return Receipt for Merchandise Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

 Yes

UNITED STATES POSTAL SERVICE



First-Class Mail  
Postage & Fees Paid  
USPS  
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •



JOE MILLER  
OHIO EPA  
401 E FIFTH ST  
DAYTON OH 45402-2911

