



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PX0005520090814

WARREN CAMP SWONEKY

WALLER, MICHELLE 2009/08/14



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 13, 2009

Captain Lloyd
605 Middleboro Road
Oregonia, Ohio 45054

RE: Camp Swoneky WWTP/Reconnaissance Inspection, NPDES Permit No.
OH0137448/ OEPA Permit No. 1PX00055*AD

Captain Lloyd:

On August 11, 2009, I conducted an NPDES Reconnaissance Inspection at the Camp Swoneky Wastewater Treatment Plant, during which Ed Machado, Caretaker, Bob Gomez, Winelco, and you were present. The purpose of the inspection was to evaluate compliance with the terms and condition of the facility's NPDES permit.

All areas that were evaluated received a satisfactory rating. No actions are recommended at this time. A copy of the inspection report is enclosed.

Ohio Administrative Code 3745-7-04 which covers treatment works and sewerage system classification and staffing requirements was also discussed. When the NPDES permit for Camp Swoneky is renewed at the end of 2010, Camp Swoneky will be rated as a Class 1 facility. As a Class 1 facility, a Class 1 operator will be required to visit the plant 3 days per week for a minimum of 1.5 hours per week.

If you have any questions, please contact me by phone at (937) 285-6028 or by e-mail at michelle.waller@epa.state.oh.us.

Respectfully,

Michelle Waller
Environmental Specialist II
Division of Surface Water

Enclosures





State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PX00055*AD	OH137448	8/10/2009	R	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Camp Swoneky 605 Middleboro Road Oregonia, Ohio	10:10 AM	12/1/2005
	Exit Time	Permit Expiration Date
	11:15 AM	11/30/2010
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Captain Lloyd Ed Machado - Caretaker Bob Gomez - Winelco, Contract Operator	(513) 932-1794 (513) 317-8673	
Name, Address and Title of Responsible Official	Phone Number	
Captain Lloyd 605 Middleboro Road Oregonia, Ohio 45054		

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measurement	S	Pretreatment
S	Records/Reports	N	Laboratory	N/A	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	S	Sludge Storage/Disposal		Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)	
Inspector	Reviewer
<i>Michelle Waller</i> 8/13/09	
Michelle Waller Division of Surface Water Southwest District Office	Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office
Date	Date

