



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1PC0000320090316

WARREN

LEBANON WWTP

WARE, RONALD

2009/03/16



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 11, 2009

Pat Clements, City Manger
City of Lebanon
50 S Broadway
Lebanon, OH 45036

**Re: Lebanon Regional WWTP, NPDES Permit No. 1PC00003*FD / OH0021059
Compliance Evaluation Inspection**

Dear Mr. Clements:

On Tuesday, March 10, 2009, Mr. Ron Ware of this office conducted a Compliance Evaluation Inspection at the above referenced facility. John Habig, Johnny Salyers, and Terry Hammons represented the City during the inspection. The purpose of the inspection was to evaluate several aspects of plant operation and performance. A copy of the inspection report is enclosed. As indicated in the report, all areas evaluated during the inspection were rated as satisfactory. No response or corrective action is required at this time.

If you have any questions regarding this report, please contact Mr. Ware at (937) 285 - 6098.

Sincerely,

Martyn Burt
Compliance and Enforcement Supervisor

cc: John Habig, City of Lebanon

MB/mab






State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PC00003*FD	OH0021059	3/10/09	C	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
City of Lebanon Regional WWTP 1525 Mason Morrow Milgrove Road Lebanon, Ohio 45036	9:35 AM	April 1, 2006
	Exit Time	Permit Expiration Date
	11:35 AM	January 31, 2010
Name(s) and Title(s) of On-Site Representatives		Phone Number(s)
John Habig, Director of Water and Wastewater		(513) 228 - 3601
Johnny Slayers, Wastewater Operations Superintendent		(513) 494 - 2386
Terry Hammons, Senior Environmental Technician		
Name, Address and Title of Responsible Official		Phone Number
Pat Clements, City Manager City of Lebanon 50 S Broadway Lebanon, OH 45036		(513) 228 - 3130

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	S	Flow Measurement	N	Pretreatment
S	Records/Reports	S	Laboratory		Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	S	Sludge Storage/Disposal		Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)			
Inspector		Reviewer	
 Ron Ware Division of Surface Water Southwest District Office		 Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office	
3/12/09 Date		3/12/09 Date	

Sections E thru K: Complete on all inspections as appropriate
Y – Yes, N – No, N/A – Not Applicable, N/E – Not Evaluated

Section E: Permit Verification

Inspection observations verify the permit

- (a) Correct name and mailing address of permittee Y
- (b) Correct name and location of receiving waters..... Y
- (c) Product(s) and production rates conform with permit application (Industries)..... N/A
- (d) Flows and loadings conform with NPDES permit..... Y
- (e) Treatment processes are as described in permit application... Y
- (f) New treatment process(es) added since last inspection..... N
- (g) Notification given to State of new, different or increased discharges..... N/A
- (h) All discharges are permitted..... Y
- (i) Number and location of discharge points are as described in permit..... Y

Comments/Status:

Section F: Compliance

- (a) Any significant violations over the past two years Y
- (b) Permittee is taking actions to resolve violations..... Y
- (c) Permittee has a compliance schedule..... N
- (d) Compliance schedule contained in
- (e) Permittee is meeting compliance schedule..... N/A

Comments/Status:

(a) Exceedances of allowable limits for Total Suspended Solids (for both concentrations and loadings) were reported at outfall 001 in December 2007. A return sludge pump failure was the reported cause of these violations.

Section G: Operation & Maintenance

Treatment Works:

Treatment facility properly operated and maintained

- (a) Standby power available.....generator or dual feed Y
- (b) Adequate alarm system available for power or equipment failures.. Y
- (c) All treatment units in service other than backup units..... Y
- (d) Wastewater Treatment Works classification (OAC 3745-7)..... IV
- (e) Operator of Record holds unexpired license of class required by permit..... Y
 Class: III
- (f) Copy of certificate of Operator of Record displayed on-site..... Y
- (g) Minimum operator staffing requirements fulfilled (OAC 3745-7)... Y
- (h) Routine and preventative maintenance scheduled/performed... Y
- (i) Any major equipment breakdown since last inspection..... Y
- (j) Operation and maintenance manual provided and maintained..... Y
- (k) Any plant bypasses over the past year N
- (l) Regulatory agency notified of bypasses..... N/A
 On MOR's and/or Spill Hotline (1-800-282-9378)
- (m) Any hydraulic and/or organic overloads since last inspection..... N

Record Keeping:

- (a) Log book provided..... Y
- (b) Format of log book (i.e. computer log, hard bound book)

Hard bound book
- (c) Log book(s) kept onsite (in an area protected from weather)..... Y
- (d) Log book contains the following:
 - I. Identification of treatment works..... Y
 - II. Date/times of arrival/departure for Operator of Record and any other operator required by OAC 3745-7..... Y
 - III. Daily record of operation and maintenance activities (including preventative maintenance, repairs and request for repairs)..... Y
 - IV. Laboratory results (unless documented on bench sheets)... Y
 - V. Identification of person making log entries..... Y
- (d) Has the operator of record submitted written notification to the permittee, Ohio EPA and (if applicable) any local environmental agencies when a collection system overflow, treatment plant bypass or effluent limit violation has occurred..... Y

Section G: Operation & Maintenance (con't)

Collection System:

- (a) Combined system? N
- (b) Any collection system overflows since last inspection..... Y
(CSO and/or SSO)
- (c) Regulatory agency notified of overflows (SSOs)..... Y
- (d) CSO O&M plan provided and implemented..... N/A
- (e) CSOs monitored and reported in accordance with permit..... N/A
- (f) Portable pumps used to relieve system..... Y
- (g) Lift station alarms provided and maintained..... Y
- (h) Are lift stations equipped with permanent standby power
or equivalent..... Y
- (i) Is there an inflow/infiltration problem (separate sewer system),
or were there any major repairs to collection system since
last inspection..... Y
- (j) Any complaints received since last inspection of basement flooding Y
- (k) Are any portions of the sewer system at or near capacity..... N

Comments/Status:

<p>Treatment Works:</p> <p>Collection System:</p>
--

Section H: Sludge Management

- (a) Sludge management plan (SMP)
Submitted date: Approval #: Not submitted N/A

- (b) Sludge management plan current..... N/A
- (c) Sludge adequately disposed..... Y
(Method: Sanitary landfill)
- (d) If sludge is incinerated, where is ash disposed of? N/A
- (e) Is sludge disposal contracted..... N
(Name:)
- (f) Has amount of sludge generated changed significantly since
last inspection..... N
- (g) Adequate sludge storage provided at plant..... Y
- (h) Land application sites monitored and inspected per SMP..... N/A
- (i) Records kept in accordance with State and Federal law..... Y
- (j) Any complaints received in last year regarding sludge..... N
- (k) Is sludge adequately processed (digestion, pathogen control)..... Y

Comments/Status:

Section I: Self-Monitoring Program

Flow Measurement:

- (a) Primary flow measuring device operated and maintained..... Y
Type of device: Ultrasonic & Parshall flume Ultrasonic & Weir Weir
Calculated from influent Other (Specify:)

- (b) Calibration frequency adequate Y

- (c) Secondary instruments operated and maintained..... Y
- (d) Flow measurement equipment adequate to handle full range
of flows..... Y
- (e) Actual flow discharged is measured..... Y
- (f) Flow measuring equipment inspection frequency
 Daily Weekly monthly other

Comments/Status:

Section I: Self-Monitoring Program (con't)

Sampling:

- (a) Sampling location(s) are as specified by permit..... Y
- (b) Parameters and sampling frequency agree with permit..... Y
- (c) Permittee uses required sampling method..... Y
- (d) Sample collection procedures are adequate..... Y
 - (i) Samples refrigerated during compositing..... Y
 - (ii) Proper preservation techniques used..... Y
 - (iii) Containers and sample holding times prior to analysis conform with 40 CFR 136.3..... Y
- (e) Monitoring records (i.e., flow, pH, DO) maintained for a minimum of three years including all original strip chart recordings (i.e., continuous monitoring instrumentation, calibration and maintenance records)..... Y
- (f) Adequate records maintained of sampling date, time, location, etc.. Y

Laboratory:

General

- (a) EPA approved analytical testing procedures used (40 CFR 136.3).. Y
 - (b) If alternate analytical procedures are used, proper approval has been obtained..... N/A
 - (c) Analyses being performed more frequently than required by permit. N
 - (d) If (c) is yes, are results in permittee's self-monitoring report..... N/A
 - (e) Commercial laboratory used..... Y
- Parameters analyzed by commercial lab: Ammonia nitrogen (quality control), total phosphorus, nitrates/nitrites, TKN, metals, total hardness, oil & grease, low level mercury, Bis(2-ethyhexyl)
- Lab name: Masi

Quality Control/Quality Assurance

- (f) Quality assurance manual provided and maintained..... Y
- (g) Satisfactory calibration and maintenance of instruments/equipment. Y
- (h) Adequate records maintained..... Y
- (i) Results of latest USEPA quality assurance performance sampling program: Satisfactory Marginal Unsatisfactory

Date:

Comments/Status:

Laboratory:

Section J: Effluent/Receiving Water Observations

Outfall Number	Outfall sign in place?	Oil sheen	Grease	Turbidity	Foam	Solids	Color	Other
1PC00003001	unknown	None	None	None	slight	None	None	-

Comments/Status:

Observations were made at disinfection/post aeration tank. The plant's final outfall is submerged in the Little Miami River.

Section K: Multimedia Observations

- (a) Are there indications of sloppy housekeeping or poor maintenance in work and storage areas or laboratories..... N
- (b) Do you notice staining or discoloration of soils, pavement or floors.. N
- (c) Do you notice distressed (unhealthy, discolored, dead) vegetation.. N
- (d) Do you see unidentified dark smoke or dust clouds coming from sources other than smokestacks..... N
- (e) Do you notice any unusual odors or strong chemical smells..... N
- (f) Do you see any open or unmarked drums, unsecured liquids, or damaged containment facilities..... N

If any of the above are observed, ask the following questions:

- (1) What is the cause of the condition?
- (2) Is the observed condition or source a waste product?
- (3) Where is the suspected contaminant normally disposed?
- (4) Is this disposal permitted?
- (5) How long has the condition existed and when did it begin?

Comments/Status:

