



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director



1IZ0002020090818

WARREN MONROE WTP

WARE, MAUREEN 2009/08/18



State of Ohio Environmental Protection Agency

Southwest District Office

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX: (937) 285-6249
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 21, 2009

Robert Takach
Monroe WTP
P.O. Box 330
Monroe, Ohio 45050

RE: Monroe WTP Reconnaissance Inspection (RI)

Ladies and Gentlemen:

On August 13, 2009, I conducted a Reconnaissance Inspection at the Monroe WTP. A copy of my inspection report is enclosed. The inspection report contains no marginal or unsatisfactory ratings.

If you have any questions or comments concerning the contents of this letter, please feel free to contact me this office.

Sincerely,

Maureen M. Ware
Division of Surface Water

cc: Butler County Health Dept.

File: Warren Co
 Monroe WTP
 Sewerage



State of Ohio Environmental Protection Agency
 Southwest District Office

NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
11Z00020	OH0072311	08/13/09	R	S	2

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Monroe WTP 51 South Union Rd. Monroe, Ohio	8:30 AM	2/1/05
	Exit Time	Permit Expiration Date
	9:15 AM	1/31/10
Name(s) and Title(s) of On-Site Representatives		Phone Number(s)
Robert Takach, Superintendent		937- 539-7374
Name, Address and Title of Responsible Official		Phone Number
Mayor and Council, City of Monroe		

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
M	Permit	N	Flow Measurement	N	Pretreatment
S	Records/Reports	N	Laboratory	N	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	N	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)

The renewal application for the Monroe WTP has not been submitted on time, hence the marginal rating for the Permit category. Mr. Takach indicated that the application would be submitted within a week. There was some plant growth on the filters. The effluent from the WTP was clear.

Inspector	Reviewer
 Maureen M. Ware Division of Surface Water Southwest District Office Date: 8/21/09	 Martyn Buft Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office Date: 8/24/09