Ohio Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

DDGWOH8563712525

February 28, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Certified Mail

James Martin
Immanuel Fellowship
7878 Twp Rd 602
Fredericksburg, OH 44627

Wayne County
Immanuel Fellowship PWS
Non-Community, Transient PWS
PWS ID: OH8563712
Facility ID: 8562039

Subject: Violation of Maximum Contaminant Level for Nitrate

Immanuel Fellowship is in violation for exceeding the maximum contaminant level (MCL) for nitrate in drinking water during January 1 to March 31, 2012. The Ohio Administrative Code (OAC) establishes an MCL of 10 milligrams per liter (mg/L) for nitrate. The average nitrate concentration was 17 mg/L for the sample(s) collected on February 23 and February 27, 2012.

As a result of receiving a MCL violation, your system must take the following actions:

1. Issue the enclosed "Drinking Water Warning" to inform customers within 24 hours from notification of the MCL violation as specified by the enclosed instructions. The enclosed public notice may be used to meet this requirement. If you wish to change the notice, contact this office prior to issuance; **AND**

2. Complete a verification form and send it with a copy of the public notice to my attention at the above mailing address within ten days of issuing a public notice; **AND**

3. Perform quarterly monitoring for nitrate during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 – December 31).

If you have any questions or wish to revise any of the notices, please call me at (614) 644-2752.

Sincerely,

Wendy Sheeran

Wendy Sheeran

Compliance Assurance Section
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form; Nitrate Fact Sheet

cc: Wayne County Health Department

50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 644 3020
614 | 644 3184 (fax)
www.epa.ohio.gov

Printed on Recycled Paper

Printed in-house

DRINKING WATER WARNING

Immanuel Fellowship water has high levels of nitrate

DO NOT GIVE THE WATER TO INFANTS UNDER 6 MONTHS OLD OR USE IT TO MAKE INFANT FORMULA OR JUICE

Results from water samples collected on February 23 and February 27, 2012 showed average nitrate levels of 17 mg/L. This is above the nitrate standard, or maximum contaminant level (MCL), of 10 mg/L. Nitrate in drinking water is a serious health concern for infants less than six months old.

What should I do?

- **DO NOT GIVE THE WATER TO INFANTS.** ***Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.*** Blue baby syndrome is indicated by blueness of the skin. Symptoms in infants can develop rapidly, with health deteriorating over a period of days. If symptoms occur, seek medical attention immediately.

- Formula for children under six months of age should not be prepared with tap water. Instead, use bottled water or other water low in nitrates when preparing infant formula until further notice.

- **DO NOT BOIL THE WATER.** Boiling, freezing, filtering, or letting water stand does not reduce the nitrate level. Excessive boiling can make the nitrates more concentrated, because nitrates remain behind when the water evaporates.

- Adults and children older than six months can drink the tap water (nitrate is a concern for infants because they can't process nitrates in the same way adults can). However, if you are pregnant, nursing or have specific health concerns, you may wish to consult your doctor.

What happened? What is being done?

Nitrate in drinking water can come from natural, industrial, or agricultural sources (including septic systems and run-off). Levels of nitrate in drinking water can vary throughout the year. We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact:

Contact Person: _____.

Phone Number: _____.

Mailing Address: _____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID: OH8563712 Facility ID: 8562039

Date distributed:_____.

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR TIER 1 VIOLATIONS

The owner or operator of a public water system with a Tier 1 violation or situation that may pose an acute risk to human health is required to notify the persons served by the public water system. Notice shall be issued as soon as practical but **no later than 24 hours** after the system learns of the violation. Public notice shall be repeated as established during consultation with Ohio EPA.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
Use one or more of the following: 1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days). 2. Public notice issued by mail or other direct delivery to each customer and service connection (where known).	**Describe actual methods used:** 1.A. Dates of posting _____ 1.B. Locations of posting _____ _____ _____ _____ 2. Date of mailing/delivery _____ _____ _____
Schools and Day-Care Facilities must notify parents or guardians of children being served by methods <u>besides</u> posting, such as a newsletter, e-mail notice, or direct mailing. For Schools and Day-Care facilities <u>only posting public notice is not sufficient</u>.	A. Method(s) _____ _____ B. Date(s) _____
If the above methods do not reach all persons served, also use any other method calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations).	A. Method(s) _____ _____ B. Date(s) _____

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

____ A public notice as shown on the other side of this sheet was issued <u>without changes</u>.

____ A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

_____
Signature of Responsible Person Date

_____
Printed Name and Title of Responsible Person

PWS NAME: Immanuel Fellowship PWS
PWSID: OH8563712
Facility ID: 8562039
COUNTY: Wayne
NITRATE MCL, AVERAGE
First Quarter of 2012; Vio Id 525

<u>For Ohio EPA Use Only:</u>
Date PN received: _____
PN acceptable: _____ PN not acceptable: _____.