



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

RECEIVED
DDAGW

2012 FEB 23 PM 2:17

RECEIVED
OHIO EPA

FEB 27 2012

Southwest District

February 22, 2012

Re: Greenlawn Condominiums
Clark County
Community Water System
PWS ID: 1204912

Greenlawn Condominiums Owners Association
Attn: Larry Crisler, President
3330 Party Lane
Springfield, OH 45504

Subject: Monthly Operating Report (MOR) Violation

Dear Greenlawn Condominium Association:

According to Ohio Administrative Code Section 3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report shall contain the free and total chlorine daily residuals in the distribution and at the plant tap. Ohio EPA has received an MOR from Greenlawn Condominiums for the month of January 2012. However, both the free chlorine residuals at the plant and in the distribution are less than 0.2 milligrams per liter (mg/L) for each day. This is below the requirement. Each community water system that disinfects by chlorination shall have a minimum of 0.2 mg/L free chlorine OR a minimum of 1.0 mg/L combined chlorine at both the plant and in the distribution. According to the January 2012 MOR report, Greenlawn Condominiums is in violation of this rule.

The results recorded on the January 2012 MOR may be inaccurate. Electronic reporting would help to eliminate inaccurate reporting.

Please contact Ohio EPA at your earliest convenience to discuss this matter at 937-285-6085.

Thank you,

Tya Darden
Division of Drinking and Groundwaters
Public Drinking Water Unit

TD/tf

cc: Operations, Ohio EPA, DDAGW, CO

ec: Clark County Health Department

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov