Environmental
Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 27, 2011

RE: **Greenlawn Condominiums**
Clark County
Community Water System
PWS ID: 1204912

Greenlawn Condominiums
Attn: Martin Shields
3314 Scottsdale Drive
Springfield, OH 45504

Subject: Monthly Operating Report

Dear Mr. Shields:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of **DECEMBER 2010**, Greenlawn Condominiums public water system did send the monthly report to this office. However, the report was sent in on January 25, 2011 and the due date was January 10, 2011. In addition, Greenlawn Condominiums is currently not monitoring the chlorine residual for both the plant and the distribution. The current report only shows results for the distribution. As explained during the Sanitary Survey and in subsequent emails to you, the rule states that both the free and total chlorine results shall be recorded for both the plant tap and the distribution. If there is no plant tap, the operator shall take the plant tap sample from the first available location. This is a violation of the rule. Greenlawn Condominiums public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month with the correct data.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

Tya Darden
Division of Drinking and Groundwaters
Public Drinking Water Unit

cc: Dave Bornino, Ohio EPA, DDAGW, CO
Clark County Health Department
Greenlawn Condos Owners Association, Attn: Jim Yoakem, 3330 Party Lane
Springfield, OH 45504

TD/rab

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov