

**Environmental
Protection Agency**

Ted Strickland, Governor
Leri Fisher, Lt. Governor
Chris Kottelsohn, Director

February 23, 2010

Re: Greenlawn Condominiums
Clark County
Community Water System
PWS ID: 1204912

Greenlawn Condominiums
Attention: Martin Shields
3314 Scotsdale Drive
Springfield, Ohio 45504

Subject: Monthly Operating Report, Failure to Submit

Dear Mr. Shields:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of **January 2010**, Greenlawn Condominiums public water system failed to send the monthly report to this office. This is a violation of the rule. Greenlawn Condominiums public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,



Tya Darden

Division of Drinking and Groundwaters
Public Drinking Water Unit

cc: Dave Evans, Ohio EPA, DDAGW, CO
Greenlawn Condos Owners Association

ec: Clark County Health Department

TD\bp