



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 16, 2011

RE: **RETURN TO COMPLIANCE**
COMPRESSOR ENGINE STACK TEST
DOMINION EAST OHIO - AUSTINTOWN
DAPC FACILITY ID: 02-50-00-0911
EMISSIONS UNIT ID: B003

CERTIFIED MAIL

Ms. Judith Box
Dominion Resources Services, Inc.
320 Springside Dr., Suite 320
Akron, Ohio 44333

Dear Ms. Box:

A compliance stack test was conducted on the above-cited engine at Dominion East Ohio - Austintown (Dominion) on April 28, 2011. This test was performed in response to the Notice of Violation (NOV) letter dated November 4, 2010. The NOV was issued for a stack test on September 28, 2010, that failed to demonstrate compliance with the volatile organic compound (VOC) limit established in the final air pollution permit-to-install and operate (PTIO) issued and effective on December 11, 2009. A copy of the compliance stack test report was received by this office via the eBusiness Center on May 25, 2011.

After a review of the report, it has been determined that, based on an average of three runs, the compressor engine demonstrated compliance with the nitrogen oxides (NO_x), carbon monoxide (CO) and VOC emission limits. Specifically, the results and limits are detailed in the following table:

Parameter Tested	Permit Limit	9/28/10 Test Result	4/28/11 Test Result
NO _x	160 ppmvd @ 15% O ₂ , 2.0 g/HP-hr	108.50 ppmvd @ 15% O ₂ , 1.264 g/HP-hr	122.2 ppmvd @ 15% O ₂ , 1.75 g/HP-hr
CO	540 ppmvd @ 15% O ₂ , 4.0 g/HP-hr	22.43 ppmvd @ 15% O ₂ , 0.159 g/HP-hr	15.4 ppmvd @ 15% O ₂ , 0.13 g/HP-hr
VOC	86 ppmvd @ 15% O ₂ , 1.0 g/HP-hr	116.68 ppmvd @ 15% O ₂ , 1.302 g/HP-hr	58.9 ppmvd @ 15% O ₂ , 0.29 g/HP-hr

This satisfies the requests in the NOV and now this facility is in compliance with stack testing requirements.

MS. JUDITH BOX
JUNE 16, 2011
PAGE 2

Please note that this letter indicating current compliance does not constitute a waiver of Ohio EPA's authority to seek civil penalties for this or any other violations as provided in ORC 3704.06 or for the U.S. EPA to seek civil penalties pursuant to federal law.

If you have any questions or need additional information, please contact me at (330) 963-1261.

Sincerely,



Jana L. Gannon
Environmental Compliance Specialist
Division of Air Pollution Control

JLG:bo

pc: Tim Fischer, DAPC, NEDO
Tom Kalman, DAPC, CO
Bill MacDowell, U.S. EPA Region V