



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 11, 2009

RE: WARNING LETTER
ANNUAL STAGE II COMPLIANCE TEST
CONCORD CORNERS SUNOCO
DAPC FACILITY ID 0243001332

CERTIFIED MAIL

Mohammad Khan
Concord Corners Sunoco
7635 Crile Rd.
Concord Twp., OH 44077

Dear Mr. Khan:

The annual Stage II compliance demonstration conducted at Concord Corners Sunoco located at 7635 Crile Rd. in Concord Twp., Ohio on February 4, 2009, demonstrated compliance with the testing requirements of Ohio Administrative Code Rule 3745-21-09 (DDD).

Our inspector noted that there were several hoses and nozzles that needed to be replaced. It is your responsibility to inspect this equipment for defects on a regular basis and to replace it when defects or leakage are found.

We also have noted that you did not conduct the required testing in 2006 or 2008. You should be aware that the Ohio Administrative Code requires that this testing be done annually.

The next Stage II compliance test is due in February 2010. This will be the five year test that includes testing of the dynamic pressure.

Further, we have noted that the facility does not have a certified Stage II specialist. We also noted in our 2007 inspection that there was not a certified Stage II specialist at the site. The Ohio Administrative Code requires that there be on site an employee that has been trained in the proper use and maintenance of the Stage II vapor control equipment. I have enclosed a flyer from your testing company about an upcoming training class.

Lastly, I have enclosed a Permit by Rule Notification form. Please complete the form and return it as per the instructions. This will replace any needed Permit-to-Operate or Permit-to-Install and will mean you no longer have to pay the biannual emission fees.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

enclosures: Permit by Rule Notification form
Stage II training flyer